

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR / AP3139FT
Name of operator	Dŵr Cymru Welsh Water
Location of Facility	Five Fords WWTW, LL13 OPA
Time and date of the detection	14:21 to 15:20 on 04/11/2015

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified immediately	
Date and time of the event	14:21 to 15:20 on 04/11/2015
Reference or description of the location of the event	Exhaust stack for CHP1 and CHP2 and natural gas boiler.
Description of where any release into the environment took place	Emission point A1 and A2, as defined in EPR/AP3139FT
Substances(s) potentially released	VOCs / TVOCs
Best estimate of the quantity or rate of release of substances	2,911.57 mg C/m ³ based on preliminary results.
Measures taken, or intended to be taken, to stop any emission	Welsh Water is awaiting further data/guidance from ECL on significance.
Description of the failure or accident.	organic compounds in excess of permit level emitted to air.

(b) Notification requirements for the breach of a permit condition	
To be notified immediately	
Emission point reference/ source	
Parameter(s)	
Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

