



Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_111
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	During the day of 25 th May 2013 (Reported by telephone Ref. 1116081)		

Any more accurate information on the matters for notification under Part A.	The cupola abatement oxidiser burner was shut off by a temperature safety limit.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Following investigation and inspection during a planned maintenance shut down period, the ABB electro pneumatic controller, a control mechanism on the burner system, was considered to be the cause of the temperature trip out, subsequently a new controller was fitted and calibrated and a two monthly routine system function test established to prevent recurrence.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	02/06/11, 13/06/11, 27/06/11, 19/07/11, 26/07/11, 27/07/11, 07/09/11, 13/09/11, 10/11/11, 13/12/11, 03/01/12, 18/01/12, 23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13.

Name*	C. Hensley
Post	Environmental Manager
Signature	<i>C. Hensley</i>
Date	14 th November 2013

* authorised to sign on behalf of Knauf Insulation Ltd

	INITIALS	DATE
OK FOR PUBLIC REGISTER	AS	21/11/13
COPIED TO PUBLIC REGISTER	JB	EDem