

RECEIVED

12 AUG 2013

Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_107
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	The evening of 26 th April 2013 Emergency By-Pass opened by safety temperature set point trip.		

Any more accurate information on the matters for notification under Part A.	None.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	From SCADA recorded alarm messages the burner appeared to have been shut off by an over-temperature safety trip. Because it had been found on previous occasions that cleaning and lubricating the burner control linkages made the burner operation more stable, this was repeated. The cause of the temperature trip-out will be investigated and appropriate action taken to prevent a recurrence. The temperature sensors in this area were checked and all found to be in good condition and working correctly.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	28/04/11, 01/05/11, 02/06/11, 13/06/11, 27/06/11, 19/07/11, 26/07/11, 27/07/11, 07/09/11, 13/09/11, 10/11/11, 13/12/11, 03/01/12, 18/01/12, 23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13.

Name*	B.K.Pratley
Post	Environmental Manager
Signature	<i>B. K. Pratley</i>
Date	12 th August 2013

* authorised to sign on behalf of Knauf Insulation Ltd

	INITIALS	DATE
OK FOR PUBLIC REGISTER	AS	15/08/13
COPIED TO PUBLIC REGISTER	JB	EOem