



Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	BR9383ID	Notification Reference	EP_EX_116
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	The day of 27 September 2013.		

(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution	
To be notified within 24 hours of detection	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

NIRS no 1162895

	INITIALS	DATE
OK FOR PUBLIC REGISTER	AS	21/10/13
COPIED TO PUBLIC REGISTER	JB	EDM

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	Cupola Furnace Main Stack, Emission Point A.
Parameter(s)	Carbon Monoxide.
Limit	Daily Average 80mg/Nm ³ @8%O ₂ Dry Gas.
Measured value and uncertainty	We estimate that the Daily Average will be about 120mg/Nm ³ @8%O ₂ Dry Gas. Uncertainty 10% Not Deleted (Deletion Not Allowed by Permit).
Date and time of monitoring	The day of 27 th September 2013.
Measures taken, or intended to be taken, to stop the emission	Since the plant restart the burner temperature has been unusually unstable and this has result in high CO emissions. We have since taken corrective actions to bring the burner temperature and CO emissions under control and will investigate the route cause of the problem in due course.

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Name*	S Griffiths
Post	Hot End Manager
Signature	Stuart Griffiths
Date	27 th September 2013

* authorised to sign on behalf of Knauf Insulation Ltd

