



## Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

### Part A

Permit Number	BR9383ID	Notification Reference	EP_EX_132
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	The day of 9 <sup>th</sup> April 2014		


<b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or fugitive emission which has caused, is causing or may cause significant pollution</b>	
<b>To be notified within 24 hours of detection</b>	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

	INITIALS	DATE
OK FOR PUBLIC REGISTER?	AS	14/04/14
COPIED TO PUBLIC REGISTER	JB	EDRM

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Emission point reference/ source	Cupola Furnace Main Stack (Emission Point A)
Parameter(s)	Carbon Monoxide
Limit	Daily Average 80mg/Nm <sup>3</sup> @8%O <sub>2</sub> Dry Gas
Measured value and uncertainty	The Dally Average CO emisslon was 279mg/Nm <sup>3</sup> @8%O <sub>2</sub> Dry Gas. Uncertainty 10% Not Deleted (Deletion Not Allowed by Permit). Full validation of CEMs data to be undertaken.
Date and time of monitoring	The day of 8 <sup>th</sup> April 2014
Measures taken, or intended to be taken, to stop the emission	A fault caused the cupola abatement oxidiser burner to trip and the furnace emissions to be directed through the emergency stack for approximately four minutes. The blast was diverted and the equipment purged itself with fresh air as required for safe operation. At the time of the release the burner was re-lit as soon as was possible and normal operation was restored as quickly as practical. The cause of the problem will be fully investigated and appropriate action taken to prevent recurrence.

<b>Time periods for notification following detection of a breach of a limit</b>	
<b>Parameter</b>	<b>Notification period</b>

<b>(c) Notification requirements for the detection of any significant adverse environmental effect</b>	
<b>To be notified within 24 hours of detection</b>	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

<b>Name*</b>	C. Hensley
<b>Post</b>	Environmental Manager
<b>Signature</b>	
<b>Date</b>	9 <sup>th</sup> April 2014

\* authorised to sign on behalf of Knauf Insulation Ltd