



Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_130
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	The evening of 12 th February 2014		

Any more accurate information on the matters for notification under Part A.	Detailed information provided in the Part A Notification.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>A valve has been fitted with an electrical switch box which indicates the position of the valve, which subsequently gives indication to the Hot End Control room if the valve is switched off.</p> <p>There is also a proposal to fit pressure transducers on both air supplies in order to trend the air supply pressures, which will subsequently alarm before tripping.</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	<p>14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13, 27/09/13, 04/11/13, 14/11/13, 20/11/13, 29/11/13, 04/12/13, 06/12/13, 20/01/14, 05/02/14.</p>

Name*	C. Hensley
Post	Environmental Manager
Signature	<i>C. Hensley</i>
Date	2 nd September 2014

* authorised to sign on behalf of Knauf Insulation Ltd

