

RECEIVED

12 SEP 2014

**Schedule 6 - Notification****Part B - to be submitted as soon as practicable**

Permit Number	BR9383ID	Notification Reference	EP_EX_123
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	The morning of 29 <sup>th</sup> November 2013		

Any more accurate information on the matters for notification under Part A.	Hot gases escaped through a faulty manifold flange, which damaged a cable, which caused the burner controller to trip.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	A new manifold flange was fitted during the Christmas shut down, however, in the interim period, the manifold flange was tightened up and cables protected with insulation.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	13/12/11, 03/01/12, 18/01/12, 23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13, 27/09/13, 04/11/13, 14/11/13, 20/11/13.

Name*	C. Hensley
Post	Environmental Manager
Signature	<i>C. Hensley</i>
Date	2 <sup>nd</sup> September 2014

\* authorised to sign on behalf of Knauf Insulation Ltd

OFF FOR PUBLIC REGISTER	INITIALS	DATE
	AS	3/9/14
COPIED TO PUBLIC REGISTER	JB	EDRM