



Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_137
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	The day of 4 th July 2014		

Any more accurate information on the matters for notification under Part A.	Detailed information provided in the Part A Notification.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	To prevent reoccurrence, the minimum and maximum pressure point set points for P100 (Cupola outlet pressure) were re-set within the SCADA control system, to limit the input fields that the operators can access.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13, 27/09/13, 04/11/13, 14/11/13, 20/11/13, 29/11/13, 04/12/13, 06/12/13, 20/01/14, 05/02/14, 12/02/14, 13/03/14, 08/04/14, 214/05/14, 29/06/14, 02/07/14.

Name*	C. Hensley
Post	Environmental Manager
Signature	
Date	2 nd September 2014

* authorised to sign on behalf of Knauf Insulation Ltd

