


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_144 EP_EX_145
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	EP_EX_144: Day of 13 th January 2015 EP_EX_145: Day of 13 th January 2015		

Any more accurate information on the matters for notification under Part A.	The releases were caused by problems associated with the modulating pneumatic valve actuator, which had previously been identified, which was resulting in excessive CO in the combustion chamber, which in turn was causing pressure and temperature fluctuations in the combustion chamber and causing burner instability.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	In consultation with Enetex, the manufacturer of the flue gas treatment plant, it was considered that this issue would be resolved by changing the current pneumatic control for the main gas burner to an electrical motor. Enetex consider the fitting of an electrical motor to be best practice. This was due to be installed during the August shutdown, however the part, which was tested before installation, was found to be faulty and therefore a new part was ordered and was received for installation during the October maintenance period.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13, 27/09/13, 04/11/13, 14/11/13, 20/11/13, 29/11/13, 04/12/13, 06/12/13, 20/01/14, 05/02/14, 12/02/14, 13/03/14, 02/04/14, 08/04/14, 21/05/14, 29/06/14, 01/07/14, 04/07/14, 11/07/14, 19/07/14, 20/07/14, 21/07/14, 8-9/10/14.

Name*	C. Hensley
Post	HSE Manager
Signature	
Date	14 th January 2015

* authorised to sign on behalf of Knauf Insulation Ltd