


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_147
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	Afternoon of 19th March 2015		

Any more accurate information on the matters for notification under Part A.	<p>A pocket of CO in the cupola furnace caused a rapid expansion of gas in the cupola furnace which blew out an explosion panel at the top of W10 pre-heater cooler. As detailed on the Part A Notification, it was identified during the third emergency by-pass opening incident that high differential pressure across the Enetex bag filter was causing the emergency by-pass to flip open. Measures, as detailed in the Part A Notification, were then taken to resolve the high differential pressures.</p> <p>The higher flow through the bag filter (F20) was a result of an air leak. The plant went off-line in order to investigate and subsequently, the blown explosion panel on W10 was detected.</p>
Measures taken, or intended to be taken, to prevent a recurrence of the incident	A temporary fix has been undertaken on the explosion panel and a new explosion panel, which will be fitted with an electrical failure detector, will be installed during the next planned shutdown (Easter shutdown in early April).
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13, 27/09/13, 04/11/13, 14/11/13, 20/11/13, 29/11/13, 04/12/13, 06/12/13, 20/01/14, 05/02/14, 12/02/14, 13/03/14, 02/04/14, 08/04/14, 21/05/14, 29/06/14, 01/07/14, 04/07/14, 11/07/14, 19/07/14, 20/07/14, 21/07/14, 8-9/10/14, 15/10/14, 11/01/15

Name*	C. Hensley
Post	HSE Manager
Signature	
Date	23 rd March 2015

* authorised to sign on behalf of Knauf Insulation Ltd