



Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_127 EP_EX_129 EP_EX_131
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	EP_EX_127: Day of 20 th January 2014 EP_EX_129: Day of 5 th February 2014 EP_EX_131: Day of 13 th March 2014		

Any more accurate information on the matters for notification under Part A.	All incidences related to the burner set-up, following the major refurbishment works undertaken on the Enetex flue gas treatment plant during the Christmas shut down. The set-up of the burner was not yet optimised during prolonged hold periods, which was resulting in high CO emissions.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Fine tuning of the burner setting was undertaken during hold periods in order to resolve the issue and is now performing comfortably within the emission limits.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13, 27/09/13, 04/11/13, 14/11/13, 20/11/13, 29/11/13, 04/12/13, 06/12/13.

Name*	C. Hensley
Post	Environmental Manager
Signature	<i>C. Hensley</i>
Date	2 nd September 2014

* authorised to sign on behalf of Knauf Insulation Ltd

	RETAILS	DATE
ON FOR PUBLIC REGISTER	<i>AS</i>	3/9/14
COPIED TO PUBLIC REGISTER	<i>JB</i>	<i>EDM</i>