



Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_115 EP_EX_116 EP_EX_118 EP_EX_119 EP_EX_120 EP_EX_124 EP_EX_125 EP_EX_126
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	EP_EX_115: Day of 27 th September 2013 EP_EX_116: Day of 27 th September 2013 EP_EX_118: Morning of 4 th November 2013 EP_EX_119: Morning of 4 th November 2013 EP_EX_120: Morning of 14 th November 2013 EP_EX_124: Day of 29 th November 2013 EP_EX_125: Day of 4 th December 2013 EP_EX_126: Day of 6 th December 2013		

Any more accurate information on the matters for notification under Part A.	All incidences related to a fault which caused the cupola abatement oxidiser burner to trip resulting in the opening of the emergency bypass stack and/or exceedance of the daily average CO emission limit.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Investigations identified that the thermocouple at T501 was over heating due to its location at the back of the burner, which was causing the burner to trip. In consultation with Enetex, the manufacturer of the flue gas treatment plant, and as part of a 120,000 Euro refurbishment during the Christmas shut down, the thermocouple was repositioned one meter up the ducting in order to prevent reoccurrence of the incident.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believe that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	10/11/11, 13/12/11, 03/01/12, 18/01/12, 23/01/12, 24/01/12, 06/02/12, 07/02/12, 14/02/12, 24/02/12, 3, 4, 5 & 6/03/12, 02/04/12, 04/04/12, 23/04/12, 01/05/12, 18/06/12, 10/08/12, 04/09/12, 19/11/12, 21/11/12, 28/11/12, 30/01/13, 07/02/13, 26/02/13, 11/03/13, 21/03/13, 22/03/13, 04/04/13, 07/04/13, 18/04/13, 26/04/13, 09/05/13, 21/05/13, 31/05/13, 25/06/13.

Name*	C. Hensley
Post	Environmental Manager
Signature	<i>C. Hensley</i>
Date	2 nd September 2014

* authorised to sign on behalf of Knauf Insulation Ltd

	INITIALS	DATE
COPIED FOR PUBLIC REGISTER	JS	3/9/14
COPIED TO PUBLIC REGISTER	JB	EORM