


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

| | | | |
|--------------------------------|---|------------------------|-----------|
| Permit Number | BR9383ID | Notification Reference | EP_EX_161 |
| Name of operator | Knauf Insulation Ltd | | |
| Location of Facility | Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA | | |
| Time and date of the detection | 2 nd August 2016 | | |

| | |
|--|---|
| Any more accurate information on the matters for notification under Part A. | As detailed on the Part A Notification. |
| Measures taken, or intended to be taken, to prevent a recurrence of the incident | <p>During the planned extended shutdown in August, further remedial work has been undertaken on the tent filter tank to address the build-up of solids, which comprised the refurbishment of the bottom screw. A re-test for ammonia and particulate matter was undertaken on 16th August following plant start-up. The results are as follows as confirm compliance:</p> <p>Particulate Matter (ELV 50mg/Nm3): Run 1: 09:15 to 10:15 9.5mg/m³ Uncertainty 1.3mg/m³ Not Deleted; Run 2: 10:25 to 11:30 15.4mg/m³ Uncertainty 1.9mg/m³ Not deleted; Run 3: 11:30 to 12:35 9.2mg/m³ Uncertainty 1.3mg/m³ Not Deleted</p> <p>Ammonia (ELV 50mg/Nm3): Run 1: 09:15 to 10:15 32.5mg/m³ Uncertainty 3.9mg/m³ Not Deleted; Run 2: 10:25 to 11:30 46mg/m³ Uncertainty 5.6mg/m³ Not deleted; Run 3: 11:30 to 12:35 47.9mg/m³ Uncertainty 5.8mg/m³ Not Deleted</p> |
| Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission | It is believed that no permanent harm will result from the incident. |
| The dates of any unauthorised emissions from the facility in the preceding 24 months. | 8-9/10/14, 15/10/14, 11/01/15, 19/03/15, 20/04/15, 19/06/15, 23/07/15, 17/08/15, 29/08/15, 11/09/15, 5-6/10/15, 6-7/10/15, 27/10/15, 02/02/16, 23/02/16, 01-15/06/16, 10/07/16. |

| | |
|-----------|---|
| Name* | C. Keouski |
| Post | HSE Manager |
| Signature |  |
| Date | 5 th September 2016 |

* authorised to sign on behalf of Knauf Insulation Ltd