


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_176
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	Day of 7 th September 2017		

Any more accurate information on the matters for notification under Part A.	A change to blast setting on start-up resulted in burner trips due to a temperature fluctuation in the combustion chamber caused by excessive CO in the combustion chamber.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	A revised start-up procedure has been implemented by the Technical Department.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	11/09/15, 5-7/10/15, 27/10/15, 02/02/16, 23/02/16, 15/06/16, 27/06/16, 28/06/16, 10/07/16, 15/08/16, 16/08/16, 13/09/16, 14/09/16, 25/04/2017, 24/05/17, 07/07/17, 04/08/17, 14/08/17, 15/08/17

Name*	C. Keouski
Post	HSE Manager
Signature	
Date	29 th November 2017

* authorised to sign on behalf of Knauf Insulation Ltd