


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_174 EP_EX_175
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	EP_EX_174: Day of 14 th August 2017 EP_EX_175: Day of 15 th August 2017		

Any more accurate information on the matters for notification under Part A.	The validated Daily Averages were as follows: EP_EX_174: Daily Average SO2 emission of 1411.45mg/Nm3 EP_EX_175: Daily Average SO2 emission of 1421.93mg/Nm3
Measures taken, or intended to be taken, to prevent a recurrence of the incident	On investigation by the CEMs equipment specialist, the O2 and Pressure input modules and H2O output module had failed as a result of the electrical power outage (external power supply (Scottish Power) cable fault), which occurred on 11 August. Thus, the oxygen reading during this period was not being corrected for oxygen resulting in CEMs data recording SO2 values in excess of the ELV. The fault was resolved following module replacements. The input and output modules were subsequently made a stock item and can be replaced by engineering personnel if/when required.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	17/08/15, 29/08/15, 11/09/15, 5-7/10/15, 27/10/15, 02/02/16, 23/02/16, 15/06/16, 27/06/16, 28/06/16, 10/07/16, 15/08/16, 16/08/16, 13/09/16, 14/09/16, 25/04/2017, 24/05/17, 07/07/17, 04/08/17

Name*	C. Keouski
Post	HSE Manager
Signature	
Date	29 th November 2017

* authorised to sign on behalf of Knauf Insulation Ltd