


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_173
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	Day of 4 th August 2017		

Any more accurate information on the matters for notification under Part A.	The validated CO Daily Average was 190mg/Nm3
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>As referenced on the Part A Notification.</p> <p>This was a mains power outage in the local area.</p> <p>The furnace abatement plant was automatically purged with air during the recovery period and subsequent re-start to remove residual CO and other flammable gases to minimise the risk of possible explosion. This purging resulted in the release of concentrations of CO over a time period with an oxygen concentration at or very close to 20.9% so that correction to 8%O2 resulted in greatly inflated values. Normal operation was regained as soon as it was safely possible to do so.</p> <p>The CO emissions prior to and post abatement system purge were below the CO ELV of 80mg/Nm3.</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	17/08/15, 29/08/15, 11/09/15, 5-7/10/15, 27/10/15, 02/02/16, 23/02/16, 15/06/16, 27/06/16, 28/06/16, 10/07/16, 15/08/16, 16/08/16, 13/09/16, 14/09/16, 25/04/2017, 24/05/17, 07/07/17

Name*	C. Keouski
Post	HSE Manager
Signature	
Date	29 th November 2017

* authorised to sign on behalf of Knauf Insulation Ltd