


Schedule 6 - Notification

Part B - to be submitted as soon as practicable

Permit Number	BR9383ID	Notification Reference	EP_EX_188
Name of operator	Knauf Insulation Ltd		
Location of Facility	Chemistry Lane, Queensferry, Deeside, Flintshire, CH5 2DA		
Time and date of the detection	Day of 10 th November 2017		

Any more accurate information on the matters for notification under Part A.	As referenced on the Part A Notification.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	<p>Since the Quarter 3 compliance monitoring, the second, six monthly visit / Quarter 4 visit has been completed and results, which were received by email on 1st December have shown compliance with the ELVs (10 mg/Nm³ for both parameters):</p> <p>Particulate Matter: Run 1: 4.5 mg/m³ Run 2: 7.1 mg/m³ Run 3 8.6 mg/m³</p> <p>Ammonia: Run 1 9.89 mg/m³ Run 2 7.35 mg/m³ Run 3 9.29 mg/m³</p>
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	It is believed that no permanent harm will result from the incident.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	27/10/15, 02/02/16, 23/02/16, 15/06/16, 27/06/16, 28/06/16, 10/07/16, 15/08/16, 16/08/16, 13/09/16, 14/09/16, 25/04/2017, 24/05/17, 07/07/17, 04/08/17, 14-15/08/17, 06/09/17, 14/09/17, 16-20/09/17, 1-3/10/17, 23/10/17

Name*	C. Keouski
Post	HSE Manager
Signature	
Date	4 th December 2017

* authorised to sign on behalf of Knauf Insulation Ltd