



Warwick Chemicals

TO: Mr I. Oakes / Miss J. Bradley
FROM: Mrs K. Cuning
DATE: 1st October 2013
Total no. of sheets: 24

Please find attached the emission results for the third quarter 2013:

- RCF49 (Reporting Quarterly Emissions for Acetic Acid from A2-A23)
 - RCF66 (Fly Ash composition 3rd quarter 2013),
 - RCF50 (Annual Boiler Emissions from A17-A19 and A21)
 - RCF52 (Six Monthly Reporting of Emissions from A14)
 - x 3 (CEM's Emissions of Particulate from A14)
 - x 3 (CEM's Emissions of TOC from A14)
 - x 3 (CEM's Emissions of Carbon Monoxide from A14)
 - x 3 (CEM's Emissions of Oxides of Nitrogen from A14)
 - x 6 (Summary of Data for July, August and September 2013)
- in accordance with the requirements of our PPC Permit BU2357

Thank you

Regards

Karen Cuning
HSE Systems Specialist

eareturn/3qu13letter (1/10/13)

MONITORING RETURNS N. WALES

	INITIALS	DATE
CHECKED vs AUTHORISATION	<i>[Signature]</i>	2/10/13
TRACKING	JB	2.10.13
OK FOR PUBLIC REGISTER	<i>[Signature]</i>	2/10/13
	JB	EDRM

Annual Reporting of Emissions to Air

REF: RCF50 AREA: Site

RELATED DOCUMENT: FILENAME: 502013

ISSUE NO. 4.0

DATE OF ISSUE: 16.06.11

PAGE: 1 of 2

Last printed 09/09/2013 15:09:00

Operator: Warwick Chemicals

Form Number: A2 / (Combustion process)

Permit Reference Number: BU2357 / AP363455

Installation: Mostyn, Flintshire

Reporting of Emissions to Air for the period: From January 2013 To: December 2013

Emission Point	Substance/Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
A16	Oxides of Nitrogen	NO LONGER	IN USE	-	-	-	-
A17	Oxides of Nitrogen	170mg/m ³ ⁽⁶⁾	151	BS EN 14792:2005	10/7/13 09:35-10:35 24/4/13 09:30-10:30	MCERTS	5.90
A18	Oxides of Nitrogen	170mg/m ³ ⁽⁶⁾	164	"	"	"	5.95
A19	Oxides of Nitrogen	170mg/m ³ ⁽⁶⁾	135	"	"	"	5.36
A21	Oxides of Nitrogen	170mg/m ³ ⁽⁶⁾	149, 151, 157	"	"	"	6.11, 6.07, 6.07
A16	Carbon Monoxide	NO LONGER	IN USE	-	-	-	-
A17	Carbon Monoxide	70mg/m ³ ⁽⁶⁾	2.3	BS EN 15058:2006	10/7/13 09:35-10:35 24/4/13 09:30-10:30	"	4.32
A18	Carbon Monoxide	70mg/m ³ ⁽⁶⁾	17.6	"	"	"	4.32
A19	Carbon Monoxide	70mg/m ³ ⁽⁶⁾	85	"	"	"	4.35
A21	Carbon Monoxide	70mg/m ³ ⁽⁶⁾	4.6, 4.9, 5.8	"	"	"	4.32, 4.32, 4.32

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum measured values.'

[2] Where an internationally recognised standard test method is used the reference number is given; Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given. -

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[6] The emission limit values for oxides of nitrogen and carbon monoxide are expressed as a maximum individual hourly average value and corrected to 273K, 101.3kPa, 3% oxygen, dry.

Signed: *M Curran*

(Authorised to sign as representative of Warwick Chemicals)

Date: 29th August 2013

TITLE :	Reporting of Emissions to Air			ISSUE NO.:	4.0
REF :	RCF49	AREA:	Responsible Care	DATE OF ISSUE:	16.06.11
RELATED DOCUMENT:	AS4362-S2/A/2			PAGE:	1 of 2
FILENAME:	493qu13	Last printed 11/07/2013 11:34:00			

Permit Reference Number	BU2357/AP3338MA
Installation :	Mostyn, Flintshire

Operator:	Warwick Chemicals
Form Number :	AI (TAED & Sodium Acetate Processes)

Annual Reporting of Emissions to Air for the period:	From	1 st July	To:	30th September 2013
---	-------------	----------------------	------------	---------------------

Emission Point	Substance/Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
A2	Acetic acid	50mg/m ³ ⁽⁶⁾	25.0	SOP5100 CD/FID/GC	10/7/13 09:00-16:15	Validation Report No. MV1ES586	+/- 10%
A3	Acetic acid	50mg/m ³ ⁽⁶⁾	46.8	"	10/7/13 09:09-16:07	"	"
A5	Acetic acid	50mg/m ³ ⁽⁶⁾	22.4	"	9/7/13 10:01-16:12	"	"
A6	Acetic acid	50mg/m ³ ⁽⁶⁾	13.4	"	9/7/13 10:15-16:23	"	"
A7	Acetic acid	50mg/m ³ ⁽⁶⁾	0.33	"	9/7/13 10:08-16:18	"	"
A20	Acetic acid	50mg/m ³ ⁽⁶⁾	0.28	"	10/7/13 08:52-16:22	"	"
A22	Acetic acid	50mg/m ³ ⁽⁶⁾	1.64	"	10/7/13 08:52-16:22	"	"
A23	Acetic acid	50mg/m ³ ⁽⁶⁾	0.52	"	10/7/13 08:52-16:22	"	"
A24	Acetic acid	50mg/m ³ ⁽⁶⁾	#	#	#	#	#

Emission point no longer monitored – plant decommissioned

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the minimum — maximum measured values

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods, used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[6] The emission limit value for acetic acid is expressed as total acetic acid and acetic anhydride (as acetic acid) as a maximum individual value, and corrected to 273K, 101.3kPa

Signed:	<i>K Curran</i>
	(Authorised to sign as representative of Warwick Chemicals)

Date:	11th July 2013
--------------	----------------



TITLE :	Reporting of Emissions to Air		ISSUE NO.	3.0
REF :	RCF66	AREA:	Responsible Care	
RELATED DOCUMENT:	AS4362 - S2/A/2		DATE OF ISSUE:	16.06.11
FILENAME:	663qu13		PAGE:	1 of 1

Last printed 27/09/2013 13:33:00

Permit Reference Number	BU2357/AP3634SJ	Operator	Warwick Chemicals
Installation	Mostyn, Flintshire	Form Number	Ash1 / Ash Disposal Change

Reporting of Fly Ash Composition for the period	from	1 st July	to	30th September 2013
---	------	----------------------	----	---------------------

Ash Composition (Metals, Dioxins, etc.)																
	Cd %	Ti %	Hg %	Pb %	Cr %	Cu %	Mn %	Ni %	As %	Co %	V %	Zn %	DIOXIN			
													WHO-TEQ ng/kg			
													Humans/ mammals	Birds	Fish	
Fly Ash	1.0	10.0	1.0	6.0	290	45	47	210	1.0	10.0	10.0	170	108.66	120.215	233.585	117.085

Signed	<i>H. Canning</i>	Date	27th August 2013
(Authorised to sign as representative of Warwick Chemicals)			



Permit Reference Number : BU2357/AP3634SJ Operator : Warwick International Limited
 Installation : Mostyn, Flintshire Form Number : A3 / (Incinerator Periodic Monitoring)

Six Monthly Reporting of Emissions to Air for the period: From 1st July To 31st December 2013

Emission Point	Substance / Parameter	Emission Limit Value	Result ⁽¹⁾	Test Method ⁽²⁾	Sample Date and Times ⁽³⁾	Accreditation/ Certification ⁽⁴⁾	Uncertainty ⁽⁵⁾
A14	Hydrogen chloride	10 mg/m ³ over minimum 1 hour period	1.01mg/m ³	BS EN 1911	8/7/13 13:50-15:56	UKAS/MCERTS	0.13
A14	Hydrogen fluoride	1 mg/m ³ over minimum 1 hour period	0.09mg/m ³	BS ISO 15713	1/7/13 14:18-15:18	UKAS/MCERTS	0.01
A14	Sulphur dioxide	50 mg/m ³ (average of 1/2-hour averages) over minimum 4 hour period	0.29mg/m ³	BS EN 14791	9/7/13 09:32-11:39	UKAS/MCERTS	0.04
A14	Cadmium & thallium and their compounds (total)	0.05 mg/m ³ over minimum 30 minute, maximum 8 hour period	<0.001mg/m ³	BS EN 14385	5/7/13 08:55-11:02	UKAS/MCERTS	-
A14	Mercury and its compounds	0.05 mg/m ³ over minimum 30 minute, maximum 8 hour period	<0.0005mg/m ³	BS EN 13211	5/7/13 08:55-11:02	UKAS/MCERTS	-
A14	Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V and their compounds (total)	0.5 mg/m ³ over minimum 30 minute, maximum 8 hour period	0.004mg/m ³	BS EN 14385	5/7/13 08:55-11:02	UKAS/MCERTS	0.002
A14	Dioxins / furans (I-TEQ) ⁵	0.1 ng/m ³ over minimum 6 hour, maximum 8 hour period	0.003ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.001
A14	Dioxin-like PCBs (WHO-TEQ Humans / Mammals) ⁶	No limit applies	0.005ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.002
A14	Dioxin-like PCBs (WHO-TEQ Fish) ⁶	No limit applies	0.0002ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.0001
A14	Dioxin-like PCBs (WHO-TEQ Birds) ⁶	No limit applies	0.007ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.002
A14	Dioxins / furans (WHO-TEQ Humans / Mammals) ⁶	No limit applies	0.003ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.001
A14	Dioxins / furans (WHO-TEQ Fish) ⁶	No limit applies	0.003ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.001
A14	Dioxins / furans (WHO-TEQ Birds) ⁶	No limit applies	0.011ng/m ³	BS EN 1948	2/7/13 09:55-16:06	UKAS/MCERTS	0.003



Emission Point	Substance / Parameter	Emission Limit Value	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
A14	Poly-cyclic aromatic hydrocarbons (PAHs) Total	No limit applies	0.656ug/m ³	ISO 113381	4/7/13 10:12-16:20	UKAS/MCERTS	0.586
A14	Anthanthrene	No limit applies	0.024	"	"	"	0.022
A14	Benzo[a]anthracene	No limit applies	0.024	"	"	"	0.021
A14	Benzo[b]fluoranthene	No limit applies	0.024	"	"	"	0.021
A14	Benzo[k]fluoranthene	No limit applies	0.024	"	"	"	0.022
A14	Benzo[b]naph(2,1-d)thiophene	No limit applies	0.024	"	"	"	0.022
A14	Benzo[c]phenanthrene	No limit applies	0.024	"	"	"	0.021
A14	Benzo[ghi]perylene	No limit applies	0.024	"	"	"	0.021
A14	Benzo[a]pyrene	No limit applies	0.024	"	"	"	0.021
A14	Cholanthrene	No limit applies	0.024	"	"	"	0.021
A14	Chrysene	No limit applies	0.024	"	"	"	0.022
A14	Cyclopenta[cd]pyrene	No limit applies	0.024	"	"	"	0.021
A14	Dibenzof[ah]anthracene	No limit applies	0.024	"	"	"	0.022
A14	Dibenzof[a,h]pyrene	No limit applies	0.024	"	"	"	0.021
A14	Fluoranthene	No limit applies	0.024	"	"	"	0.021
A14	Indof[1,2,3-cd]pyrene	No limit applies	0.024	"	"	"	0.021
A14	Naphthalene	No limit applies	0.292	"	"	"	0.264

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[6] The result to be reported as a range based on: All congeners less than the detection limit assumed to be zero as a minimum, and all congeners less than the detection limit assumed to be at the detection limit as a maximum

Signed	 (authorised to sign as representative of Warwick International Limited)	Date
		29th August 2013.


Incinerator Summary Report - July 2013

Day	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Residue	24	24	24	20.5	22.5	21	20.5	24	24	21.5	24	22.5	13.5	11.5	14.5	22	18	19
Gas	0	0	0	1.5	1.5	3	5	0	0	3	0	1.5	1.3	1.6	14.5	3	6.5	6.5
Residue & gas	0	0	0	1.5	0.5	0	1.5	0	0	0.5	0	0	2.5	3.5	5	1	0.5	1.5
Idle	0	0	0	0	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0
Total flow	10894.8	10800	10799.8	8780.5	10662.2	9532.2	8738.2	10800	10800	9401.3	10799.7	10127.2	5422.7	3753.3	5308.2	12420.3	9801.3	9743.2
Gas	0	0	0	727.2	222.7	529.3	737.3	0	0	465.5	0	236.7	1901.8	2434.7	2095.8	439.3	950	968.2
Air	14257.2	14058.7	14482.7	14317.2	13985.0	14029.5	14302.3	14744.9	14584.6	14584.6	14196.8	14521.7	13456.1	12906.5	13667.9	17389.1	16293.0	16066.4
Min	309.7	257.3	212.3	67.3	204	111.7	52.7	198.3	241.3	90.3	153	127.7	114	112.3	65	49	67.7	74.3
Ave	351.1	336.9	257	237	290.6	218.8	244.7	271.8	320.4	272.6	253	237.9	305.6	415.2	322	130.5	209.2	217
Max	352	381.3	292.3	796	698.7	886.3	546	332	369.7	492.3	437.3	715.3	550	737.7	723.7	563.3	744.7	687.3
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
CO (normalised)	-5.4	-5.5	-5.5	-5.4	-5.5	-5.5	-5.5	-5.5	-5.1	-4.4	-4.2	-4.4	-4.5	-4.4	-4.3	-4.5	-4.5	-4.4
Ave	-4.6	-4.9	-5.1	-4.3	-4.7	-4.9	-4.6	-4.7	-4.1	-3.8	-4	-3.9	-3.3	-2	-2.5	-3.8	-3.9	-3.4
Max	0	0	0	0.8	0	1.2	1	0	0	2	0	0	0.6	1.1	2.3	0.6	1.1	1.1
30m ELV exceedances	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Particulates (normalised)	0.4	0.5	0.4	0.4	0.4	0.4	0.3	0.7	0.7	0.3	0.7	0.7	0.8	0.6	0.2	0.3	0.3	0.4
Ave	0.6	0.8	0.5	0.7	0.6	0.6	0.7	0.8	0.6	0.9	0.7	0.8	1.1	0.8	0.8	0.5	0.6	0.6
Max	1	1.2	0.7	0.9	0.8	0.8	0.8	1	0.9	1.1	0.9	1.1	1.2	1.1	1.2	0.7	0.7	0.8
30m ELV exceedances	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
VOC (normalised)	0.5	0.5	0.5	0	0	1	0.7	1	1	0.8	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4
Ave	0.5	0.5	0.5	0.3	0.2	1	1	1	1	1	0.7	0.5	0.7	0.9	0.8	0.5	0.6	0.6
Max	0.5	0.5	0.5	0.7	1	1.4	1.3	1.4	1	1.1	1	1	1.1	1.4	1.4	0.8	1.1	0.9
20m ELV exceedances	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


NOTES
Invalid data points are not reported because the incinerator is not operated at any time whilst CEM equipment is being maintained or calibrated


Day	19	20	21	22	23	24	25	26	27	28	29	30	31	TOTALS
Running time	8.5	8	23.5	0	0	5	16	21	24	22.5	21.5	23	18	562
Residue	20	20	0.5	2	7	20	9.5	3.5	0	2	3.5	1	8.5	176
Gas	4.5	4	0	0	0	1	2.5	0.5	0	0.5	1	0	2.5	34.5
Residue & gas	0	0	0	22	17	0	1	0	0	0	0	0	0	40.5
Idle														
Total flow	2524.5	3107.2	13534.2	0	0	2382.3	8278.5	13151	16500	15452.3	14618.2	14443	9169.7	281.2 tonnes
Residue	3004.5	3023.7	39.5	288.2	944.2	2811.7	1418.3	523.3	0	243.2	474.2	187.2	1122.8	25795 m3
Gas	129918	129249	168968	130525	216816	119422	160762	191783	230313	218234	211854	201677	160944	4850486 m3
Air														
Min	140.7	134.7	156.3			94	69	92	98.7	141.7	170.1	98.7	75.3	
Ave	439.2	391.7	282.8			216	167.6	178.5	145.5	257.4	137.4	656	229.4	
Max	801.7	599.7	459.7			428.7	501	527.3	234.7	562	457	666	618	
Exceeds daily ELV ?	Y	N	N											2 exceedances
CO (normalised)														
Min	-4.1	-4.4	-4			-4.1	-4.5	-5.5	-3	-4	-3.5	-4.5	-4.5	
Ave	-1.4	-2.2	-4			-2.6	-3.2	-3.1	1.8	-2.6	-2.2	-3.8	-3.2	
Max	1.6	1.2	0			1.3	1.5	0.7	0	0.5	0	0	1.8	
30m ELV exceedances	0	0	0			0	0	0	0	0	0	0	0	0 exceedances
Exceeds daily ELV ?	N	N	N											0 exceedances
Particulates (normalised)														
Min	0.5	0.4	0.4			0.6	0.3	0.4	0.7	0.6	0.7	0.5	0.4	
Ave	0.8	0.6	0.5			0.7	0.6	0.7	0.8	0.7	0.7	0.7	0.7	
Max	1	0.8	0.6			0.8	0.8	0.9	0.8	0.9	0.9	0.8	0.9	
30m ELV exceedances	0	0	0			0	0	0	0	0	0	0	0	0 exceedances
Exceeds daily ELV ?	N	N	N											0 exceedances
VOC (normalised)														
Min	0.5	0.4	0.4			1.5	0	0	0	0	0	0	0	
Ave	1	0.8	0.5			1.7	0.8	0.3	0.3	0.2	0.3	0.1	0.2	
Max	1.3	1.3	0.5			2.3	1.6	0.9	0.5	0.5	0.5	0.7	1	
30m ELV exceedances	0	0	0			0	0	0	0	0	0	0	0	0 exceedances
Exceeds daily ELV ?	N	N	N											0 exceedances


NOTES
 Invalid data points are not reported because the incinerator is not operated at any time whilst CEM equipment is being maintained or calibrated.



July 2013







Incinerator Summary Report - August 2013


Day	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Running time	15	23	24	22	21	24	24	24	24	21.5	24	24	24	24	24	24	24	24
Residue	10	1.5	0	5	3.5	0	0	0	0	3.5	0	0	0	0	0	0	0	0
Gas	2.5	0.5	0	3	1	0	0	0	0	1.5	0	0	0	0	0	0	0	0
Residue & gas	1.5	0	0	3	0.5	0	0	0	0	1.5	0	0	0	0	0	0	0	0
Idle																		
Total flow	80532	147655	145082	116795	110072	90278	89918	84583	83997	72462	8795	89998	9000	9000	85997	9000	9000.2	9000.2
Residue	14192	2097	0	521.8	448	0	0	0	0	426.2	0	0	0	0	0	0	0	0
Gas	168918	209778	195771	162176	152316	104486	105343	102325	102271	105868	108967	109350	110324	115513	117675	113381	115671	117417
Air																		
NOx (normalised)	35.3	163.3	176.3	79	167.3	289	203	255	229.3	142.7	198	188.7	182.3	145.7	131.7	92	136.7	184
Min	349.4	225.4	280.8	265.9	263	346	262.7	319.4	300.6	300	270.5	236.9	230.8	195.2	153.7	136.3	189.1	240.4
Ave	934.7	561.3	421	615	488.7	383.7	295.3	369.3	376.7	676.3	355.3	258	252	249.3	184.3	156	222.3	287.7
Max																		
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
CO (normalised)	-4	-4.3	-4.5	-4.5	-4.1	-4	-4	-4.1	-4	-4.1	-4	-4	-4	-4	-4	-4	-4	-4
Min	-2.7	-3.5	-4.2	-3.8	-3.8	-4	-4	-4	-4	-3.7	-4	-4	-4	-4	-4	-4	-4	-4
Ave	1	0	0	1.1	1	0	0	0	0	0.9	0	0	0	0	0	0	0	0
Max	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
20m ELV exceedances																		
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Particulates (normalised)	0.5	0.8	0.7	0.5	0.6	0.5	0.6	0.6	0.6	0.4	0.5	0.4	0.4	0.4	0.4	0.7	0.7	0.5
Min	0.8	0.9	0.8	0.8	0.7	0.6	0.7	0.7	0.6	0.6	0.6	0.5	0.5	0.6	0.7	0.7	0.7	0.6
Ave	1	0.9	0.8	0.9	0.9	0.7	0.8	0.8	0.8	0.8	0.8	0.7	0.7	0.8	0.8	0.8	0.8	0.7
Max	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
30m ELV exceedances																		
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
VOC (normalised)	0.1	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.5	0	0	0	0	0	0	0.1
Min	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.4	0.5	0.4	0.3	0.2	0.1	0.1	0.1	0.2
Ave	1.1	0.8	0.5	0.9	0.9	0.5	0.5	0.5	0.5	0.9	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
Max	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
20m ELV exceedances																		
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N

NOTES
 Invalid data points are not reported because the incinerator is not operated at any time whilst CEM equipment is being maintained or calibrated


Incinerator Summary Report - August 2013

Day	19	20	21	22	23	24	25	26	27	28	29	30	31	TOTALS
Running time	24	24	24	24	24	24	24	24	24	24	24	20	21	719.5
Gas	0	0	0	0	0	0	0	0	0	0	0	2.5	3	29
Residue & gas	0	0	0	0	0	0	0	0	0	0	0	0.5	0.5	9.5
Idle	0	0	0	0	0	0	0	0	0	0	0	2	0.5	5
Total flow	9000	9000	9000	9000	9000	9000	9000	9000	9000	9000	9000	7845.7	8250.7	292.4 tonnes
Gas	0	0	0	0	0	0	0	0	0	0	0	373.7	462.7	3961 m3
Air	116422	116947	116604	116996	113059	117824	125315	126783	125680	127321	126482	135216	122630	3904639 m3
NOx (normalised)	176	194.3	162.3	166.7	141.7	178	138.3	136.7	154	181	153.3	93.3	53	
Min	242.9	235.2	218.9	216.1	202.1	234.7	191.5	176.7	191.5	244.4	311.6	432	277	
Ave	284.3	280.3	248.3	251	222	292.3	252	211.3	218	303.7	861	864.7	783.7	
Max														
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	Y	N	N	1 exceedances
CO (normalised)	-4	-4.1	-4	-4	-4	-4	-4	-4	-4	-4	-4	-4.1	-4.2	
Min	-4	-4	-4	-4	-4	-4	-4	-4	-4	-4	-4	-3.9	-3.6	
Ave	0	0	0	0	0	0	0	0	0	0	0	0	0	
Max	0	0	0	0	0	0	0	0	0	0	0	0	0	
30m ELV exceedances														0 exceedances
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	0 exceedances
Particulates (normalised)	0.4	0.6	0.7	0.7	0.7	0.5	0.4	0.7	0.6	0.6	0.6	0.5	0.3	
Min	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.7	0.7	0.6	0.7	0.7	0.6	
Ave	0.8	0.8	0.8	0.9	0.8	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.7	
Max	0	0	0	0	0	0	0	0	0	0	0	0	0	
30m ELV exceedances														0 exceedances
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	0 exceedances
VOC (normalised)	0.4	0.2	0.1	0.2	0.4	0.4	0.2	0.4	0.4	0.5	0.1	0.2	0.5	
Min	0.5	0.5	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.9	
Ave	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	
Max	0	0	0	0	0	0	0	0	0	0	0	0	0	
30m ELV exceedances														0 exceedances
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	0 exceedances

NOTES
Invalid data points are not reported because the incinerator is not operated at any time whilst CEM equipment is being maintained or calibrated




August 2013





Title: Reporting Incinerator CEM Particulates
Area: Manufacturing
Issue No.: 1
Ref: BU2357/AP3634 A4
Last printed: 03/09/2013
Date of Issue: 21/12/2006
Related Document: BU2357/AP3634 A4
Created on: 21-12-2006
Page: 1 of 1






Title: Reporting Incinerator CEM TOC
Ref:
Related Document: BU2357/AP3634 A5

Area: Manufacturing
Last printed: 03/09/2013
Created on: 21-12-2006

Issue No.: 1
Date of Issue: 21/12/2006
Page: 1 of 1



Incinerator Summary Report - September, 2013

Day	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Running time	17	24	24	24	18	21	24	17	9	23.5	24	24	24	24	24	24	24	24
Residue	7.5	0	0	0	6	3	0	3.5	3.5	1	0	0	0	0	0	0	0	0
Gas	0.5	0	0	0	0	0	0	1	0.5	0.5	0	0	0	0	0	0	0	0
Residue & gas	0	0	0	0	0	0	0	4.5	12	0	0	0	0	0	0	0	0	0
Idle	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total flow	6393.7	8975.5	8000.7	8999.7	6817.8	8101.5	9568.8	6518.5	3880.3	10455.2	10801.2	9461.5	8400.2	8400.2	8139.2	9600.5	9600.8	9600.5
Gas	1232.2	12.8	0	0	860.2	436.3	0	501.2	581.2	112.7	0	0	0	0	0	0	0	0
Air	11640.7	119482	118241	117936	117236	112343	113443	93504	62971	137836	136569	122561	103899	105028	113816	119256	118060	118948
NOx (normalised)	Min	101	119	101.7	134.3	89.7	71.3	0	123.3	55	126.3	108.7	93.7	88	77.3	71.3	91.7	120.3
Ave	205.9	163.8	122	206	195.4	78	78.5	39	259.1	176.8	214.6	133.5	120.7	113.3	93.9	90.8	114	148.9
Max	516.7	534	138	263.3	686	134	87.7	85.7	794	631.3	320	170.3	137.3	133	110.3	99.3	130.3	178.7
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
CO (normalised)	Min	-4.3	-4.1	-4	-4	-4	-4	-4.3	-7.5	-7.3	-7	-7	-7	-7	-7	-7	-7	-7
Ave	-3.9	-4	-4	-4	-3.9	-3.7	-4	-3.8	-7	-6.9	-7	-6.8	-6.8	-6.9	-6.8	-7	-6.9	-7
Max	0	0	0	0	0	0	0	0.9	0	0	0	0	0	0	0	0	0	0
30m ELV exceedances	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
Particulates (normalised)	Min	0.3	0.4	0.7	0.4	0.5	0.4	0.3	0.4	0.5	0.9	1	1.1	0.9	0.8	0.7	0.8	0.8
Ave	0.5	0.6	0.7	0.6	0.6	0.5	0.4	0.4	0.6	0.8	0.9	1.1	1.1	1.1	0.9	0.8	0.8	0.8
Max	0.6	0.8	0.8	0.8	0.7	0.6	0.4	0.5	0.7	0.9	1	1.2	1.2	1.1	1	0.9	0.8	0.9
30m ELV exceedances	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N
VOC (normalised)	Min	0.7	0.7	0.7	0.7	0.5	0.2	0	0.3	0	0.5	0.3	0.4	0.2	0	0	0	0
Ave	1.1	0.9	0.9	0.9	0.8	0.5	0.3	0.3	0.5	0.3	0.5	0.5	0.5	0.4	0.1	0	0	0
Max	1.8	1.5	1	1	1.5	1.9	0.5	0.7	1.1	0.7	0.5	0.5	0.5	0.5	0.5	0	0	0
30m ELV exceedances	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Exceeds daily ELV ?	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N


NOTES
Invalid data points are not reported because the incinerator is not operated at any time whilst CEM equipment is being maintained or calibrated

Title: Reporting Incinerator CEM
Ref: BU2357/AP3634
Area: Manufacturing
Last printed: 01/10/2013
Created on: 21-12-2006

Incinerator Summary Report - September 2013

Day	19	20	21	22	23	24	25	26	27	28	29	30	TOTALS
Running time	24	9	17.5	9	0	0	0	0	0	0	0	0	453
Residue	0	12.5	3.5	1	0	0	0	0	0	0	0	0	41.5
Gas	0	2	0	0	0	0	0	0	0	0	0	0	4.5
Residue & gas	0	4.5	3	14	24	24	24	24	24	24	24	24	230
Residue	9501.7	3020.7	7577.7	4087.7	0.3	4.5	1	2.7	0.3	1.7	1.2	0.5	178.1 tonnes
Gas	0	1878.2	500.5	119.7	0	0	0	0	0	0	0	0	6355 m3
Air	120244	148323	110639	136519	6739	12013	13716	6473	20933	16466	10210	15431	2666241 m3
NOx (normalised)	123	34.3	41	192.7									
Ave	152.1	195.4	189	249.2									
Max	176	382.7	621.7	355									
Exceeds daily ELV ?	N	N	N	N									0 exceedances
CO (normalised)	-7	-7	-7.4	-7									
Ave	-5.9	-5.9	-5.3	-5.6									
Max	0	0.7	0	0									
30m ELV exceedances	0	0	0	0									0 exceedances
Exceeds daily ELV ?	N	N	N	N									0 exceedances
Particulates (normalised)	0.8	0.3	0.1	0.7									
Ave	0.9	0.7	0.5	0.7									
Max	1	0.9	0.7	0.7									
30m ELV exceedances	0	0	0	0									0 exceedances
Exceeds daily ELV ?	N	N	N	N									0 exceedances
VOC (normalised)	0	0.2	0.1	0.5									
Ave	0.2	0.5	0.5	0.5									
Max	0.5	0.8	1	0.5									
30m ELV exceedances	0	0	0	0									0 exceedances
Exceeds daily ELV ?	N	N	N	N									0 exceedances


NOTES
Invalid data points are not reported because the incinerator is not operated at any time whilst CEM equipment is being maintained or calibrated




September 2013



Title: Reporting Incinerator CEM Carbon Monoxide
Ref:
Related Document: BU2357/AP3634 A6
Area: Manufacturing
Last printed: 01/10/2013
Created on: 21-12-2006
Issue No.: 1
Date of Issue: 21/12/2006
Page: 1 of 1



September 2013





Title: Reporting Incinerator CEM TOC

Issue No.: 1

Ref:

Date of Issue: 21/12/2006

Related Document: BU2357/AP3634 A5

Area: Manufacturing

Page: 1 of 1

Last printed: 01/10/2013

Created on: 21-12-2006

