

FORM WATER 3: Oil emissions to controlled water – Weekly samples (W3) and annual sample (W4)

Permit Number: EPR/KP3036AX

Operator: Puma Energy (UK) Limited

Installation Location: Milford Haven Terminal, Milford Haven, SA73 3JD

Q2 2022

Parameter: Oil

Release Point	W3 discharge to St. Botolph's stream		
Parameter	ELV mg/l	3-month average of weekly samples (mg/l)	Maximum weekly result (mg/l)
Oil	5	1	1

Release Point	W4 discharge to Rickeston water	
Parameter	ELV (mg/l)	Annual sample (mg/l)
Oil	5	-

Signed *Sarah Jones*

Name Sarah Jones

On behalf of the Operator Puma Energy (UK) Limited

Date 05/07/2022

