

Permit Reference Number: EPR/MP3239FQ
 Operator: Tradebe Healthcare National Limited
 Form Dated 20 October 2011
 Installation: Wrexham Clinical Waste Incinerator

Variation Reference Number: EPR/MP3239FQ V002
 Form Number: Agency Form / A1/ AP3538SM/

Reporting of Emissions to Air for the period from January 2016 to June 2016

Emission Point	Substance / Parameter	Emission Limit Value	Result Note 1	Test Method Note 2	Sample Date and Times Note 3	Accreditation/ Certification Note 4	Uncertainty Note 5
A1	Particulate Matter mg/m ³	20 mg/m ³ periodic over minimum 1-hour period	6.4	BS EN 13284-1	16/2/201 10:35 – 11:05, 11:06 – 11:36	UKAS & MCERTS	+/- 12.2%
A1	Total Organic Carbon (TOC) mg/m ³	20 mg/m ³ periodic over minimum 1-hour period	0.67	BS EN 12619	18/2/201 15:00 – 19:00	UKAS & MCERTS	+/- 100%
A1	Oxides of Nitrogen (as NO ₂) mg/m ³	400 mg/m ³ periodic over minimum 4-hour period	352	BS EN 14792	18/2/201 15:00 – 19:00	UKAS & MCERTS	+/- 8.4%
A1	Carbon Monoxide mg/m ³	100 mg/m ³ periodic over minimum 4-hour period	0.43	BS EN 15058	18/2/201 15:00 – 19:00	UKAS & MCERTS	+/- 364%
A1	Sulphur Dioxide mg/m ³	200 mg/m ³ periodic over minimum 4-hour period	0.22	BS EN14791	17/2/201 09:44 – 12:29, 12:31 – 13:46	UKAS & MCERTS	+/- 10.9%
A1	Hydrogen chloride mg/m ³	30 mg/m ³ periodic over minimum 1-hour period	18.2	BS EN 1911	19/2/201 12:10 – 12:26, 12:27 – 12:43	UKAS & MCERTS	+/- 11%
A1	Hydrogen fluoride mg/m ³	2 mg/m ³ periodic over minimum 1-hour period	0.2	BS ISO 15713	16/2/201 13:24 – 14:24	UKAS & MCERTS	+/- 10.4%
A1	Cadmium & thallium and their compounds (total) mg/m ³	0.05 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	<0.001	BS EN 14385	16/2/201 12:06 – 12:36, 12:37 – 13:07	UKAS & MCERTS	+/- 17.6
A1	Mercury and its compounds mg/m ³	0.05 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	0.008	BS EN 13211	16/2/201 12:06 – 12:36, 12:37 – 13:07	UKAS & MCERTS	+/- 15.2
A1	Sb, As, Pb, Cr, Co, Cu, Mn, Ni and V and their compounds (total) mg/m ³	0.5 mg/m ³ periodic over minimum 30 minute, maximum 8 hour period	0.002	BS EN 14385	16/2/201 12:06 – 12:36, 12:37 – 13:07	UKAS & MCERTS	+/- 16.8
A1	Dioxins / furans (I-TEQ) ⁶ ng/m ³	0.1 ng/m ³ periodic over minimum 6 hours, maximum 8 hour period	0.011 – 0.012	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%

Emission Point	Substance / Parameter	Emission Limit Value	Result Note 1	Test Method Note 2	Sample Date and Times Note 3	Accreditation/ Certification Note 4	Uncertainty Note 5
A1	Dioxin-like PCBs (WHO-TEQ Humans / Mammals) ⁶ ng/m ³	No limit applies	0.0026 – 0.0029	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%
A1	Dioxin-like PCBs (WHO-TEQ Fish) ⁶ ng/m ³	No limit applies	0.0002 – 0.0002	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%
A1	Dioxin-like PCBs (WHO-TEQ Birds) ⁶ ng/m ³	No limit applies	0.0141 – 0.0146	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%
A1	poly-cyclic aromatic hydrocarbons (PAHs) ug/m ³	No limit applies	1.0	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Dioxins / furans (WHO-TEQ Humans / Mammals) ⁶ ng/m ³	No limit applies	0.010 - 0.010	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%
A1	Dioxins / furans (WHO-TEQ Fish) ⁶ ng/m ³	No limit applies	0.011 – 0.011	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%
A1	Dioxins / furans (WHO-TEQ Birds) ⁶ ng/m ³	No limit applies	0.017 – 0.018	BS EN 1948	17/2/201 09:27 – 12:27, 12:29 – 15:29	UKAS & MCERTS	+/- 22%
A1	Anthranthrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[a]anthracene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[b]fluoranthene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[k]fluoranthene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[b]naph(2,1-d)thiophene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[c]phenanthrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[ghi]perylene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Benzo[a]pyrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Cholanthrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%

Emission Point	Substance / Parameter	Emission Limit Value	Result Note 1	Test Method Note 2	Sample Date and Times Note 3	Accreditation/ Certification Note 4	Uncertainty Note 5
A1	Chrysene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Cyclopenta(c,d)pyrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Dibenzo[ah]anthracene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Dibenzo[a,i]pyrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Fluoranthene ug/m ³	No limit applies	0.06	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Indo[1,2,3-cd]pyrene ug/m ³	No limit applies	<0.03	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%
A1	Naphthalene ug/m ³	No limit applies	0.61	BS ISO 11338	18/2/2016 09:31 – 12:31, 12:33 – 15:33	UKAS & MCERTS	+/- 21.8%

Note 1 The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Note 2 Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.

Note 3 For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

Note 4 The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

Note 5 The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Note 6 The result to be reported as a range based on: All congeners less than the detection limit assumed to be zero as a minimum, and all congeners less than the detection limit assumed to be at the detection limit as a maximum

SignedT Hudson.....
(Authorised to sign as representative of Tradebe Healthcare National Limited)

Date.....29/7/16.....