Warwick Chemicals
Mostyn, Holywell, Flintshire. CH8 9HE
Telephone: (01745) 560651 Fax: (01745) 562215

To:	**Mr Ian Oakes, Natural Resources Wales Inspector, Natural Resources Wales, Chester Road, Buckley, Flintshire, CH7 3AT**
Email address:	**north.wales.ppc@cyfoethnaturiolcymru.gov.uk**

Sent By:	**Mr P. J. Bryant**
Position:	**HSES Manager**

PART A NOTIFICATION (Schedule 1) IN ACCORDANCE WITH CONDITION 5 (5.1.1 and 5.1.2) OF PPC PERMIT NUMBER BU 2357

Report Ref. No.: 26/04/2017 - A

Name of Operator:	Warwick International Group Limited
Location of Installation:	Dock Road Mostyn HOLYWELL Flintshire CH8 9HE
Date of this Report:	27/04/2017

Substances Emitted Which May Cause Harm		Solids
Emission:	*Time:* *Date:* *Location:*	13.27hrs -15.27hrs 26/04/2017 W1, Waste Water effluent Plant discharge point
Authorised Emission Limit for this Emission Point		250mg/l
Estimate of Emission Quantity or Rate and Duration of the Emission:		Solid content was 456 mg/l Quantity discharged was 555m^3 Duration of the discharge was two hours, between 13.27hrs -15.27hrs
Environmental Medium into Which the Emission Took Place		Water
Measures Taken (or Intended to be Taken) to Stop the Emission		Sample taken late during the discharge and analysed has given the out of consent result. Discharge completed before the final result was known.

Signed:	
Name:	**Mr P. J. Bryant**
Position:	**HSES Manager**

Date:	27/04/2017

Time:	22.05hrs