

TITLE :	Part 'A' Reporting Form			ISSUE NO.	12.0
REF :	RCF19	AREA:	SITE	DATE OF ISSUE:	08.05.13
RELATED DOCUMENT:	WI903 – Appendix C			PAGE:	1 of 1
FILENAME:	Part A Form 20082017-A			Last printed 21/08/2017 08:45:00 Created on 21/08/2017 08:37:00	



Warwick Chemicals
 Mostyn, Holywell, Flintshire. CH8 9HE
 Telephone: (01745) 560651 Fax: (01745) 562215

To:	Mr Ian Oakes, Natural Resources Wales Inspector, Natural Resources Wales, Chester Road, Buckley, Flintshire, CH7 3AT
Email address:	north.wales.ppc@cyfoethnaturiolcymru.gov.uk

Sent By:	Mr P. J. Bryant
Position:	HSES Manager

**PART A NOTIFICATION (Schedule 1) IN ACCORDANCE WITH
 CONDITION 5 (5.1.1 and 5.1.2) OF PPC PERMIT NUMBER BU 2357**

Report Ref. No.: 20/08/2017 - A

Name of Operator:	Warwick International Group Limited
Location of Installation:	Dock Road Mostyn HOLYWELL Flintshire CH8 9HE
Date of this Report:	21/08/2017

Substances Emitted Which May Cause Harm	Solids
Emission: Time: 12.35hrs – 14.35hrs Date: 20/08/2017 Location: W1, Waste Water Treatment Plant discharge point	
Authorised Emission Limit for this Emission Point	250mg/l
Estimate of Emission Quantity or Rate and Duration of the Emission:	Average solid content was 305 mg/l Quantity discharged was 997.8m ³ Duration of the discharge was two hours, between 12.35hrs and 14.35hrs
Environmental Medium into Which the Emission Took Place	Water
Measures Taken (or Intended to be Taken) to Stop the Emission	Discharge completed before the final result was known.

Signed:	
Name:	Mr P. J. Bryant
Position:	HSES Manager

Date:	21/08/2017
--------------	------------

Time:	08.35hrs
--------------	----------