

TITLE :	Part 'A' Reporting Form		ISSUE NO.	12.0
REF :	RCF19	AREA:	SITE	DATE OF ISSUE: 08.05.13
RELATED DOCUMENT:	WI903 – Appendix C	Last printed 22/05/2018 08:48:00		PAGE: 1 of 1
FILENAME:	Part A Form 21052018 - A		Created on 22/05/2018 08:44:00	



Warwick Chemicals
Mostyn, Holywell, Flintshire. CH8 9HE
Telephone: (01745) 560651 Fax: (01745) 562215

To:	Mr Ian Oakes, Natural Resources Wales Inspector, Natural Resources Wales, Chester Road, Buckley, Flintshire, CH7 3AT
Email address:	north.wales.ppc@cyfoethnaturiolcymru.gov.uk

Sent By:	Mr P. J. Bryant
Position:	HSES Manager

**PART A NOTIFICATION (Schedule 1) IN ACCORDANCE WITH
CONDITION 5 (5.1.1 and 5.1.2) OF PPC PERMIT NUMBER BU 2357**

Report Ref. No.: 21/05/2018 - A

Name of Operator:	Warwick International Group Limited
Location of Installation:	Dock Road Mostyn HOLYWELL Flintshire CH8 9HE
Date of this Report:	22/05/2018

Substances Emitted Which May Cause Harm	Solid content in waste water discharge
Emission:	Time: 17.33hrs and 19.33hrs
	Date: 21/05/2018
	Location: W1, Waste Water Treatment Plant discharge point
Authorised Emission Limit for this Emission Point	250 mg/m ³
Estimate of Emission Quantity or Rate and Duration of the Emission:	Quantity of waste water discharged 849.9m ³ discharged over a period of 120 minutes with a solid content of 393mg/m ³
Environmental Medium into Which the Emission Took Place	Water
Measures Taken (or Intended to be Taken) to Stop the Emission	Discharge had finished before the final discharge analysis was carried out. The pre-discharge sample result was 83mg/m ³

Signed:	
Name:	Mr P. J. Bryant
Position:	HSES Manager

Date:	22/05/2018
--------------	------------

Time:	08.40hrs
--------------	----------

