

TITLE :	Part 'A' Reporting Form			ISSUE NO.	12.0
REF :	RCF19	AREA:	SITE	DATE OF ISSUE:	08.05.13
RELATED DOCUMENT:	WI903 – Appendix C			PAGE:	1 of 1
FILENAME:	Part A Form 28052018 - A			Last printed 29/05/2018 06:32:00 Created on 29/05/2018 06:18:00	



Warwick Chemicals
 Mostyn, Holywell, Flintshire. CH8 9HE
 Telephone: (01745) 560651 Fax: (01745) 562215

To:	Mr Ian Oakes, Natural Resources Wales Inspector, Natural Resources Wales, Chester Road, Buckley, Flintshire, CH7 3AT
Email address:	north.wales.ppc@cyfoethnaturiolcymru.gov.uk

Sent By:	Mr P. J. Bryant
Position:	HSES Manager

**PART A NOTIFICATION (Schedule 1) IN ACCORDANCE WITH
 CONDITION 5 (5.1.1 and 5.1.2) OF PPC PERMIT NUMBER BU 2357**

Report Ref. No.: 28/05/2018 - A

Name of Operator:	Warwick International Group Limited
Location of Installation:	Dock Road Mostyn HOLYWELL Flintshire CH8 9HE
Date of this Report:	29/05/2018

Substances Emitted Which May Cause Harm	Solid content in waste water
Emission: Time: Date: Location:	13.39hrs and 15.39hrs. 28/05/2018 W1, Waste Water Treatment Plant discharge point
Authorised Emission Limit for this Emission Point	250 mg/l
Estimate of Emission Quantity or Rate and Duration of the Emission:	Quantity of waste water discharged 997m ³ discharged over a period of 120 minutes. Solid content was 290 mg/l
Environmental Medium into Which the Emission Took Place	Water
Measures Taken (or Intended to be Taken) to Stop the Emission	Discharge was completed before the final analysis results were known. Pre-discharge sample was within specification.

Signed:	
Name:	Mr P. J. Bryant
Position:	HSES Manager

Date:	29/05/2018
--------------	------------

Time:	06.15hrs
--------------	----------