

RECEIVED

10 APR 2013

Schedule 1 - Notification of abnormal emissions

Part A

Permit Number	WP3836ZF		
Name of Operator	SITA Healthcare Ltd		
Location of Installation	Wrexham		
Location of the emission	A1		
Time and date of the emission	14:00 – 14:29 09.04.13		
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
VOC	Air	22.56 mg/m ³	14:00 to 14:29
Measures taken, or intended to be taken, to stop the emission		Waste feed stopped	

Part B

Any more accurate information on the matters for notification under Part A.	The ID fan tripped which caused combustion problems. There is scheduled maintenance for the ID fan in the planned April shutdown.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	Waste feed stopped.
The dates of any unauthorised emissions from the Installation in the preceding 24 months.	<p><u>CO</u>(12,16,17,22/04/11)(12,15,20,21/5/11),(2,3,5,9,14,15,23,28/6/11) 02/07/2011, 25/07/11 19/09/11, 20/09/11, 23/09/2011,,16.11.11</p> <p><u>TOC</u>(29/6/11)(29.03.12) 17/07/11 21/07/2011 16.11.11 18.01.12, 22.01.12, 25.02.12, 24.12.12</p> <p>16.02.13, 14.03.13</p> <p><u>HCl</u> 25.07.12, 27.09.12,</p> <p><u>Dust</u> 29/11/11, 01/12/11, 21/06/12, 31.12.12</p>
Name	Emma Old/ Rita Greenwood
Post	Environment Support Manager/ Senior Plant Manager
Signature	Rita Greenwood
Date	10.04.13

OK FOR PUBLIC REGISTER

INITIALS

DATE

COPIED TO PUBLIC REGISTER

16.4.13

L.C 10.5.13

JB EDM.