

RECEIVED
02 MAY 2013

Schedule 1 - Notification of abnormal emissions

Part A

Permit Number		WP3836ZF	
Name of Operator		SITA Healthcare Ltd	
Location of Installation		Wrexham	
Location of the emission		A1	
Time and date of the emission		01.30 – 01.59 on 01/05/2013	
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
VOC	Air	21.28 mg/m ³	01.30 – 01.59
Measures taken, or intended to be taken, to stop the emission		Stopped loading waste until emission levels dropped below permitted emission value	

Part B

Any more accurate information on the matters for notification under Part A.	After loading a waste container into the incinerator, the emission levels spiked and quickly dropped back down again
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	Will monitor waste from this source in future in case of future breaches.
The dates of any unauthorised emissions from the Installation in the preceding 24 months.	<p><u>CO</u> 12,15,20,21/5/11),(2,3,5,9,14,15,23,28/6/11) 02/07/2011, 25/07/11 19/09/11, 20/09/11, 23/09/2011,,16.11.11</p> <p><u>TOC</u>(29/6/11)(29.03.12) 17/07/11 21/07/2011 16.11.11 18.01.12, 22.01.12, 25.02.12, 24.12.12</p> <p>16.02.13, 14.03.13, 09.04.13, 19.04.13</p> <p><u>HCl</u> 25.07.12, 27.09.12,</p> <p><u>Dust</u> 29/11/11, 01/12/11, 21/06/12, 31.12.12</p>
Name	Alan Gartside
Post	Senior Plant Manager
Signature	<i>Alan Gartside</i>
Date	02/05/2013

VOC breach notified . 18.04.13
33.7 mg/m³
09.04.13
22.56 mg/m³

OK FOR PUBLIC REGISTER	INITIALS	DATE
	L.C	10.5.13
COPIED TO PUBLIC REGISTER	JB	EORM