

RECEIVED

02 MAY 2013

STERILE TECHNOLOGIES GROUP LTD	FORM		No / Level: SP6.4
	Date: 1/01/06	Issue: 1	Page: 1 of 1

NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION

Notification in accordance with PPC permit condition 5.1.1.6

Permit number: WP3836ZF

Name of operator: SITA Wrexham

Location of installation: Marlborough Rd, Wrexham

Location of emission: Release Point A2 – Incinerator Emergency Relief Vent

The emergency relief vent opened at: 02:50 on 02/05/2013

Duration of operation: 517 minutes

Reasons for operation: ID fan trip

Measures taken to prevent a reoccurrence: Plant put into shutdown due to ID Fan belt failure, these have been replaced.

The plant returned to normal operation at: 11:27 on 02/05/2013

The loading of waste ceased while the emergency relief vent was open.

Notified by: Alan Gartside

Position: Senior Plant Manager

Notification completed at : 16:15 on 02/05/2013

OK FOR PUBLIC REGISTER	INITIALS	DATE
	A.C.	10.5.13
JB EORM.		

STERILE TECHNOLOGIES GROUP LTD	FORM		No / Level: SP6.4
	Date: 1/01/06	Issue: 1	Page: 1 of 1

NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION

Notification in accordance with PPC permit condition 5.1.1.6

Permit number: WP3836ZF

Name of operator: SITA Wrexham

Location of installation: Marlborough Rd, Wrexham

Location of emission: Release Point A2 – Incinerator Emergency Relief Vent

The emergency relief vent opened at: 02:50 on 02/05/2013

Duration of operation: 517 minutes

Reasons for operation: ID fan trip due fan belts breaking, Kiln clear of waste after 120 mins.

Measures taken to prevent a reoccurrence: The Id Fan belts will be inspected during each scheduled shutdown and changed as and when is necessary

2nd version as requested

The plant returned to normal operation at: 11:27 on 02/05/2013

The loading of waste ceased while the emergency relief vent was open.

Notified by: Alan Gartside

Position: Senior Plant Manager

Notification completed at : 16:15 on 02/05/2013

OK FOR PUBLIC REGISTER	INITIALS	DATE
	KC	10.5.13
COPIED TO PUBLIC REGISTER	JB	EDRM