

STERILE TECHNOLOGIES GROUP LTD	FORM		No / Level: SP6.4
	Date: 1/01/06	Issue: 1	Page: 1 of 1

**NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION**

**RECEIVED**  
10 APR 2013

Notification in accordance with PPC permit condition 5.1.1.6

Permit number: WP3836ZF

Name of operator: SITA Wrexham

Location of installation: Marlborough Rd, Wrexham

Location of emission: Release Point A2 – Incinerator Emergency Relief Vent

The emergency relief vent opened at: 14:00 on 09/04/2013

Duration of operation: 19 minutes

Reasons for operation: ID fan trip

Measures taken to prevent a reoccurrence: There is scheduled maintenance for the ID fan in the planned April shutdown.

The plant returned to normal operation at: 14:29 on 09/04/2013

The loading of waste ceased while the emergency relief vent was open.

Notified by: Rita Greenwood

Position: Senior Plant Manager

Notification completed at : 15:30 on 09/04/2013

	INITIALS	DATE
OK FOR PUBLIC REGISTER	<i>[Signature]</i>	16.4.13
COPIED TO PUBLIC REGISTER	JB	EDrm