

RECEIVED

n 8 AUG 2013

STERILE TECHNOLOGIES GROUP LTD	FORM		No / Level: SP6.4
	Date: 1/01/06	Issue: 1	Page: 1 of 1

NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION

Notification in accordance with PPC permit condition 5.1.1.6

Permit number: WP3836ZF

Name of operator: SITA Wrexham

Location of installation: Marlborough Rd, Wrexham

Location of emission: Release Point A2 – Incinerator Emergency Relief Vent

The emergency relief vent opened at: 09:11 on 08/08/2013

Duration of operation: 8 minutes

Reasons for operation: Incinerator temperatures too high and tripped the ID Fan

Measures taken to prevent a reoccurrence: Stopped loading the incinerator and allowed temperatures to cool inside the process

The plant returned to normal operation at: 09:19 on 08/08/2013

The loading of waste ceased while the emergency relief vent was open.

Notified by: Alan Gartside

Position: Senior Plant Manager

Notification completed at: 15:49 on 08/08/2013

	INITIALS	DATE
OK FOR PUBLIC REGISTER	LC	6.9.13
COPIED TO PUBLIC REGISTER	JB	EORM