

STERILE TECHNOLOGIES GROUP LTD	FORM		No / Level: SP6.4
	Date: 1/01/06	Issue: 1	Page: 1 of 1

**NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION**

Notification in accordance with PPC permit condition 5.1.1.6



Permit number: WP3836ZF

Name of operator: SITA Wrexham

Location of installation: Marlborough Rd, Wrexham

Location of emission: Release Point A2 – Incinerator Emergency Relief Vent

The emergency relief vent opened at: 16:52 on 12/02/2014

Duration of operation: 1 minutes

Reasons for operation: Emergency Vent was operated by a power surge due to exceptional bad weather

Measures taken to prevent a reoccurrence: Power cuts on the Industrial Estate are uncontrollable in bad weather, because of this we stopped loading until the strength of the wind had decreased dramatically.

The plant returned to normal operation at: 16:53 on 12/02/2014

The loading of waste ceased while the emergency relief vent was open.

Notified by: Alan Gartside

Position: Senior Plant Manager

Notification completed at : 14:00 on 13/02/2014

	INITIALS	DATE
OK FOR PUBLIC REGISTER	R.C.	18.2.14
OK FOR PUBLIC REGISTER	JB	EP/CM