



# Schedule 1 • Notification of abnormal emissions

## Part A

Permit Number		EPRIWP3836ZF	
Name of Operator		SITA Healthcare Ltd	
Location of Installation		Wrexham Clinical Waste Incinerator, Marlborough Road, Wrexham Industrial Estate, Wrexham LL13 9RJ	
Location of the emission		A1	
Time and date of the emission		10:48 – 11:18 & 11:20 – 11:50 on 30 JUNE 2014 (Report Received 17 July 2014)	
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Mercury (Bi-annual re-test)	Air	35 mg/m <sup>3</sup>	10:48 – 11:18 & 11:20 – 11:50
Measures taken, or intended to be taken, to stop the emission		No issues have been reported or initially identified with the combustion or abatement operations but further investigation into the abatement system will be carried out by a third party contractor. In house Mercury monitoring shall be carried out to determine if the non-consenting result was atypically high, potentially due to an input to the Incinerator. All customer's waste streams will be assessed to try and identify the potential source of any high Mercury containing wastes.	

Name*	Stephen Blay
Post	SHEQ Officer
Signature	
Date	18 July 2014

• authorised to sign on behalf of SITA Healthcare Limited

