

STERILE TECHNOLOGIES GROUP LTD	FORM		No / Level: SP6.4
	Date: 1/01/06	Issue: 1	Page: 1 of 1

## NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION

Notification in accordance with PPC permit condition 5.1.1.6

Permit number: WP3836ZF

Name of operator: SITA Wrexham

Location of installation: Marlborough Rd, Wrexham

Location of emission: Release Point A2 – Incinerator Emergency Relief Vent

The emergency relief vent opened at: 11:30 on 29/10/14

Duration of operation: 17 minutes

Reasons for operation: There was a brief power cut to the site which interrupted plant operations. It also knocked off the computers on site including the one that controls the plant operation. Additional time was taken to reboot this computer and the plant returned to normal.

Measures taken to prevent a reoccurrence: Power restored and computer rebooted.

The plant returned to normal operation at: 11:47 on 29/10/2014

The loading of waste ceased while the emergency relief vent was open.

Notified by: Alan Gartside

Position: Senior Plant Manager

Notification completed at : 09:00 on 30/10/2014