



Schedule 1 - Notification of abnormal emissions

Part A

Permit Number		WP3836ZF	
Name of Operator		SITA Healthcare Ltd	
Location of Installation		Wrexham	
Location of the emission		A1	
Time and date of the emission		10.30 – 10.59 on 23/08/14	
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
SO ₂ (1/2 hourly average)	Air	440.28 mg/m ³ (ELV 200 mg/m ³)	10.30 -10.59
Measures taken, or intended to be taken, to stop the emission		Stopped loading waste	

Part B

Any more accurate information on the matters for notification under Part A.	After loading a waste container into the incinerator from Bin Number DO 01331 from Tradebe Doncaster emission levels quickly spiked on SO ₂ . Efforts were made by the Shift Leader to contact the EA hotline but could not get through as there was no answer
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	Will monitor waste from this source in future in case of future breaches. Commercial Manager for Tradebe Doncaster Informed to liaise with the waste producer(s)
The dates of any unauthorised emissions from the Installation in the preceding 24 months.	Mercury: 10.4.14, 30.6.14 TOC: 24.12.12, 16.02.13, 14.03.13, 09.04.13, 19.04.13, 01.05.13 SO₂: 24.12.13 HCl: 27.09.12, Particulate Matter: 31.12.12, 14.11.2013
Name	Alan Gartside
Post	Senior Plant Manager
Signature	<i>Alan Gartside</i>
Date	27/08/14

