



Permit and introduction note: PPC regulations

Schedule 1 – Notification of abnormal emissions

Part C

Permit Number	WP3836ZF
Name of Operator	SITA Healthcare Limited – Wrexham Clinical Waste Incinerator
Location of Installation	Wrexham

Time at which abnormal operation commenced	01.30 on 07/02/2014							
Time at which abnormal operation ceased	02.30 on 07/02/2013							
Duration of this incidence of abnormal operation	60 minutes							
Cumulative abnormal operation duration in current year (at end of present incidence)	90 minutes							
Reasons for abnormal operation	Lime pipe blockage in the pipework that feeds fresh lime to the abatement system. The blockage is more than likely as a result of the issues with the Vibration Horn that we suffered 2/02/2014 as previously reported under abnormal operations.							
How did the abnormal operation end? (e.g. plant repaired, reaching maximum permitted duration, initiation of shutdown, etc.)	Stopped loading & removed the Lime pipe blockage was cleared and emission levels returned to below ELV. Lime pipes have been replaced to plastic piping with more access points so that we can clear blockages more readily.							
Where the abnormal operation was caused by the failure of the particulate, CO or TOC CEM, attach a copy of the alternate monitoring data which was used to demonstrate compliance with the abnormal operation emission limit values.								
Where abatement plant has failed, give the half-hourly average emissions for pollutants of relevance during the abnormal operation in the rows below mg/m ³								
Pollutant	1 st ½ hour	2 nd ½ hour	3 rd ½ hour	4 th ½ hour	5 th ½ hour	6 th Hour	7 th ½ hour	8 th ½ hour
HCl								
SO2	240.16	201.14						
CO								
NOx								
VOC								
Dust								

Name*	Alan Gartside
Post	Senior Plant Manager
Signature	
Date	07/02/2014

* authorised to sign on behalf of SITA Healthcare Limited, Wrexham Clinical Waste Incinerator

