

NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION

Notification in accordance with PPC permit condition 5.1.1.6

Permit number:	WP3836ZF
Name of operator:	Tradebe Healthcare National Limited
Location of installation	Marlborough Rd, Wrexham Industrial Estate, Wrexham LL13 9RJ
Location of emission:	Release Point A2 – Incinerator Emergency Relief Vent
The emergency relief vent opened at:	17:15 29/2/2016
Duration of operation:	3 hour 11 minute
Reasons for operation:	Failure of waste heat boiler water level instrument. The instrument failed to low low water action point which initiated the ERV opening as per design
Measures taken to prevent a reoccurrence:	The waste heat boiler water level instrument was replaced
The plant returned to normal operation at:	20:26

The loading of waste ceased while the emergency relief vent was open.

Notified by: Toby Hudson

Position: SHEQ Manager

Notification completed at: 17:25 3/3/2016