

## **NOTIFICATION OF EMERGENCY RELIEF VENT OPERATION**

Notification in accordance with PPC permit condition 5.1.1.6

Permit number:	WP3836ZF	
Name of operator:	Tradebe Healthcare National Limited	
Location of installation	Marlborough Rd, Wrexham Industrial Estate, Wrexham LL13 9RJ	
Location of emission:	Release Point A2 – Incinerator Emergency Relief Vent	
The emergency relief vent opened at:	12:50	27/07/2016
Duration of operation:	0 hour 11 minute	
Reasons for operation:	We encountered elevated temperatures during a controlled drugs destruction. This resulted in high kiln face temperature which in turn resulted in an increase in the boiler temperature which initiated the automatic safety system	
Measures taken to prevent a reoccurrence:	Due to the high combustion rate of the drugs in future these bins are to be blended into the waste stream rather than put through the incinerator consecutively.	
The plant returned to normal operation at:	13.29hrs	

The loading of waste ceased while the emergency relief vent was open.

Notified by: Ian Roberts

Position: Site Manager

Notification completed at: 11.38 28/7/2016