

Performance parameters

Permit Number: **EPR/BB3599CW** Operator: **Next Generation Data Limited**
 Facility: **Newport Data Centre** Form Number: **Performance1 / 22/04/2020**

Reporting of other performance indicators for the period 22/04/2020 to 31/12/2020

Parameter	Value	Units
Diesel usage	14.39	m ³

Parameter	Value		Units
Generator annual operation in emergency scenario	0		Number of runs
	Run	Duration of run	
	N/A	N/A	N/A

Operator's comments: The permit was determined 22/04/2020 and therefore the data recorded in this form constitutes that from permit determination onwards. There were no emergency outages between 22/04/2020 and 31/12/2020.

Signed
 (Authorised to sign as representative of Operator)

Date...29/01/2021.....

S. KINCHI

Permit Number: EPR/BB3599CW
Facility: Newport Data Centre

Operator: Next Generation Data Limited
Form Number: Testing and Maintenance/
22/04/2020

Reporting of other performance indicators for the period 22/04/2020 to 31/12/2020

Parameter	Value		Units
Generator annual operation in maintenance/testing scenario	136 hours 26 minutes (as per attached)	Total hours for the site	Hours
	See attached	Total hours per generator	Hours
	See attached	Total number of runs per generator	Quantity
	See attached	Number of minutes per run	Minutes

Operator's comments: The permit was determined 22/04/2020 and therefore the data recorded in this form constitutes that from permit determination onwards. It should be noted that due to COVID restrictions maintenance activities were limited. Cells coloured grey (see attached) were identified by the operator as erroneous readings as the generators had not been run in November, and this has been confirmed by the maintenance contractor WBPS in the attached.

Signed
(Authorised to sign as representative of Operator)

Date...29/01/2021.....

S. KINCHI