

Schedule 6 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	BU7545IM
Name of operator	The Valspar (UK) Corporation Limited
Location of Installation	Parkway, Deeside industrial park
Time and date of the detection	13/12/2016 @ 11:30hrs

((a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident or fugitive emission which has caused, is causing or may cause pollution	
To be notified within 24 hours of detection	
Date and time of the event	13/12/2016 @ 11:30hrs
Reference or description of the location of the event	Odour detected on site and on the boundary by Iceland
Description of where any release into the environment took place	Unclear where the release has emitted from, this is still being investigated from a previous occurrence
Substances(s) potentially released	Unknown substances as the investigation is still ongoing to identify the source of the release, which once located, will determine what substances were involved
Best estimate of the quantity or rate of release of substances	The quantity and rates are unknown due to not knowing how long the issues was going on
Measures taken, or intended to be taken, to stop any emission	Outside contractor employed to review the set up. Review of our current abatement on all emission points ongoing
Description of the failure or accident.	The initial investigation identified the following points and will be rectified by the site maintenance team: The scrubber fluid was low The pipework had low points that could cause pooling The pumps were too big for the task Still awaiting the full report on other points by the specialist contractor

(b) Notification requirements for the breach of a limit	
To be notified within 24 hours of detection unless otherwise specified below	
Emission point reference/ source	Not yet confirmed the exact location of the release point
Parameter(s)	Not yet known
Limit	Unknown
Measured value and uncertainty	Unknown
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	Full investigation currently underway to identify that the system is functioning correctly. An independent contractor that specializes in these scrubber systems attended site and made some

Permit Number BU7545IM

	recommendations for the scrubber
--	----------------------------------

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) Notification requirements for the detection of any significant adverse environmental effect	
To be notified within 24 hours of detection	
Description of where the effect on the environment was detected	Odour was detected on the site boundary opposite Iceland
Substances(s) detected	Unknown
Concentrations of substances detected	Unknown
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The maintenance team are working through a list of recommendations issued by the specialist contractor to ensure the scrubber system is working effectively.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Emission point A5 to be reviewed and look into adding a fan and/or abatement to assist with dispersion
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name* Scott Bragg	
Post – SHE Manager	
Signature 	
Date –10/1/2017	

* authorised to sign on behalf of The Valspar (UK) Corporation Limited