

Permit Number: RP3637SY

Operator: SITA (UK) Ltd.

Installation: Marlborough Rd., Wrexham Ind. Est., Wrexham **Form Number:** Air1 / 01/06/06

Reporting of emissions to air for the period from July to September 2014.

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
Shredder							
A1	Total aerobic bacteria	1000 cfu/m ³	1m 40s	116	Ref. Q4049	17/9/14 13:25	3.15%
A1	Total coliform bacteria	300 cfu/m ³	1m 40s	< 1	Ref. Q4049	17/9/14 13:39	13.55%
A1	Total fungi	1000cfu/m ³	1m 40s	172	Ref. Q4049	17/9/14 13:31	3.15%
Holoflite							
A2	Total aerobic bacteria	1000 cfu/m ³	1m 40s	480	Ref. Q4049	17/9/14 14:01	3.15%
A2	Total coliform bacteria	300 cfu/m ³	1m 40s	1	Ref. Q4049	17/9/14 14:04	13.55%
A2	Total fungi	1000 cfu/m ³	1m 40s	520	Ref. Q4049	17/9/14 14:07	3.15%

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(Authorised to sign as representative of Operator)

Date.....