ENVIRONMENTAL MANAGEMENT RECORD

Subject: Reporting of Emissions to Water for 3 Months	Doc Id: WX-EMS-0015-EMR Revision: 2 Date: APRIL 2010

PERMIT REFERENCE NUMBER: BV 8016 ID, KP 3135 LW & EPR BV 8016 ID

OPERATOR: Kellogg Company of Great Britain Ltd

INSTALLATION: Wrexham Breakfast Cereals **FORM NUMBER:** W1 **REPORTING PERIOD:** 1st July – 30th September 2016

CHEMICAL OXYGEN DEMAND

Emission Point	Maximum/mg l^{-1}		Minimum/mg l^{-1}		Average/mg l^{-1}	Number of results
	Value	Date	Value	Date		
W1	44	02.08.16	0	02.07.16	3.4	92
W2	37	09.09.16	0	01.07.16	3.4	92

BIOLOGICAL OXYGEN DEMAND

Emission Point	Emission Limit Value (mg/l)	Maximum/mg l^{-1}		Minimum/mg l^{-1}		Average/mg l^{-1}	Number of results
		Value	Date	Value	Date		
W1	30	6	27.07.16	1	10.08.16	2.7	13
W2	30	6	13.07.16	1	03.08.16	3.4	13

SUSPENDED SOLIDS

Emission Point	Emission Limit Value (mg/l)	Maximum/mg l^{-1}		Minimum/mg l^{-1}		Average/mg l^{-1}	Number of results
		Value	Date	Value	Date		
W1	50	20	15.07.16	0	20.07.16	3.2	92
W2	50	22	19.08.16	0	01.07.16	3.3	92

Signed: D C Edwards **Print Name:** DARRAN EDWARDS

(Authorised to sign as representative of the Operator) **Date:** 12/10/2016