

Permit Number: EPR/RP3237SZ/T001

Operator: Tradebe Healthcare National Limited

Facility: Wrexham Clinical Waste Treatment & Transfer Station

Form Number: Sewer1 / 28/10/2011

Reporting of emissions to sewer for the period from 1st June to 30th June 2018

Emission Point	Substance / Parameter	Emission		Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value	Reference Period				
S1	Flow	--	Reported as daily average over one month.	57.1 m ³ /day	BS EN 872	-	-

The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Environment Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

SignedPaul Phillips.....

Date.....04/07/2018.....