

Schedule 1 • Notification of abnormal emissions

Part A

Permit Number		EPR/WP3636ZG	
Name of Operator		Tradebe Healthcare Ltd	
Location of Installation		Wrexham Heat Disinfection Unit, Marlborough Road, Wrexham Industrial Estate, Wrexham LL13 9RJ	
Location of the emission		A2	
Time and date of the emission		10:34 on 6 August 2015 (Report Received 26 August 2015)	
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Fungi Quarterly	Air	2712 cfu/m3	10:34
Measures taken, or Intended to be taken, to stop the emission		The contractor who carried out the monitoring has recommended the following actions: Investigate and if necessary clean Scrubber Investigate air flow through the system	

Name*	Stephen Blay
Post	SHEQ Officer
Signature	,
Date	26 August 2015

• authorised to sign on behalf of Tradebe Healthcare Limited