

Schedule 1 • Notification of abnormal emissions

Part A

Permit Number		EPR/WP3636ZG	
Name of Operator		Tradebe Healthcare Ltd	
Location of Installation		Wrexham Heat Disinfection Unit, Marlborough Road, Wrexham Industrial Estate, Wrexham LL13 9RJ	
Location of the emission		A2	
Time and date of the emission		10:34 on 6 August 2015 (Report Received 26 August 2015)	
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Fungi Quarterly	Air	2712 cfu/m ³	10:34
Measures taken, or Intended to be taken, to stop the emission		The contractor who carried out the monitoring has recommended the following actions: Investigate and if necessary clean Scrubber Investigate air flow through the system	

Part B

Any more accurate information on the matters for notification under Part A.	Scrubber was cleaned and HEPA filter replaced. Re-test completed. Result: 872 CFU/ m ³
Measures taken, or Intended to be taken, to prevent a recurrence of the incident	Complete a full review of the abatement system to ensure it is working correctly and to assess whether the system can be simplified.

Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	No action appropriate
The dates of any unauthorised emissions from the Installation in the preceding 24 months.	8 th September 2014, 8 th July 2014

Name*	Stephen Blay
Post	SHEQ Officer
Signature	,
Date	28 September 2015

• authorised to sign on behalf of Tradebe Healthcare Limited