

Schedule 1 • Notification of abnormal emissions

Part A

Permit Number		EPR/WP3636ZG	
Name of Operator		Tradebe Healthcare National Ltd	
Location of Installation		Wrexham Clinical Waste treatment Facility (HDU & TS), Marlborough Road, Wrexham Industrial Estate, Wrexham LL13 9RJ	
Location of the emission		A1 & A2	
Time and date of the emission		22 January 2016 (Report Received 12/2/2016)	
Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
A1 (Shredder) Fungi	Air	3800 cfu/m ³	11:09 22/1/2016
A2 (HDU) Fungi	Air	3240 cfu/m ³	11:27 22/1/2016
A2 (HDU) Bacteria	Air	1640 cfu/m ³	11:29 22/1/2016
Measures taken, or Intended to be taken, to stop the emission		<p>The HEPA filters on both A1 and A2 will be replaced. It had also been identified separately that the HEPA filter housing prior to the A2 release point showed signs of wear and will be replaced.</p> <p>A retest shall be undertaken to confirm the effectiveness of the actions</p>	

Name*	Toby Hudson
Post	SHEQ Manager
Signature	T Hudson
Date	15 th February 2016

• authorised to sign on behalf of Tradebe Healthcare Limited