

Schedule 1 - Notification of abnormal emissions

These pages outline the information that the operator must provide. To satisfy conditions 5.11 and 5.1.2 of this permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	AP3633HT
Name of operator	Vion Food Group (Wales & West of England) Ltd
Location of Installation	Glendale Avenue, Sandycroft, Flintshire
Location of the emission	Roof void above DMR Off Line Packing
Time and date of the detection	22 nd January 2013 0730hrs

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
R22 Refrigerant	Gas	242kg	0730am to 1100am

Measures taken, or intended to be taken, to stop the emission	The system was immediately isolated and was pressure tested and leak checked. Damaged pipe work found will be replaced. System will then be pressure checked to ensure on leak is still present following the repairs.
---	--

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	The information entered in part A is correct and no amendments required
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The system was checked by a refrigeration engineer who investigated the leak and he found that there was a part of the pipe that had rubbed against the wall which caused a leak. To prevent this from happening again they have fitted additional pipe supports so this cannot happen.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	This has been forward on as part of the original report sent to EAW.

2.2.5

OK FOR PUBLIC REGISTER	INITIALS	DATE
	SL	25.6.13
COPIED TO PUBLIC REGISTER	JB	EORm

Name* STE	STEVEN VAN DER KIEFT
Post	OHSE Mgr.
Signature	S. Van der Kieft
Date	15-4-13

* authorised to sign on behalf of Vion Food Group (Wales & West of England) Ltd