

Schedule 1 - Notification of abnormal emissions

These pages outline the information that the operator must provide. To satisfy conditions 5.11 and 5.1.2 of this permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	AP3633HT
Name of operator	Vion Food Group (Wales & West of England) Ltd
Location of Installation	Glendale Avenue, Sandycroft, Flintshire
Location of the emission	Plant room 3 air cooled condenser
Time and date of the detection	1300 4/07/13

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
R22 REFRIGERANT	GAS	Hard to quantify as a very small leak on a condenser	1300 on the 4 th of July 2013

Measures taken, or intended to be taken, to stop the emission	Leak found during quarterly manual leak check ,plant to be shut down on Friday 5 th of July, plant to be pumped down. all remaining gas in the condenser to be reclaimed , leak repaired and pressure tested. all reclaimed gas to be put back into the system and returned to service .
---	---

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the installation in the preceding 24 months.	

Name*	MURRAY JOHNSTON
Post	Maintenance Manager

Schedule 1 - Notification of abnormal emissions

These pages outline the information that the operator must provide. To satisfy conditions 5.11 and 5.1.2 of this permit.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the PPC Regulations.

Part A

Permit Number	AP3633HT
Name of operator	Vion Food Group (Wales & West of England) Ltd
Location of installation	Glendale Avenue, Sandycroft, Flintshire
Location of the emission	Plant room 3 air cooled condenser
Time and date of the detection	1300 4/07/13

Substance(s) emitted	Media	Best estimate of the quantity or the rate of emission	Time during which the emission took place
R22 REFRIGERANT	GAS	Hard to quantify as a very small leak on a condenser	1300 on the 4 th of July 2013

Measures taken, or intended to be taken, to stop the emission	Leak found during quarterly manual leak check, plant to be shut down on Friday 5 th of July, plant to be pumped down, all remaining gas in the condenser to be reclaimed, leak repaired and pressure tested. all reclaimed gas to be put back into the system and returned to service.
---	---

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	Leak located to a return pipe in the fin area of the condenser. Pipe re connected by passing the leaking return pipe. Please find attached service engineers reports. This was a very small leak. Loss on the total system that small could not be quantified.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	The systems are subject to quarterly manual leak checks as part of a preventative maintenance scheme. Continue with checks as per the scheme of examination.
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the	




**Installations, Service and Spares For All Makes of Refrigeration and Air Conditioning Equipment
Industrial, Commercial and Marine**

Email: enquiries@totaltechnical.co.uk

DAY	DATE	STARTED	ENDED	NORM	OVER	PARTS	USED	REQ.	QTY	
MON										
TUE										
WED										
THUR						LEAK SPRA	✓			
FRI	5-7-13									
SAT										
SUN										
	TOTALS									
EQUIPMENT		MAKE		MODEL		SERIAL NO.	ASSET NO.	REF	CYLINDER NO.	QTY

AUTHORISING SIGNATURE		DESCRIPTION	QUANTITY	AMOUNT EXC. OF V.A.T. (£)	V.A.T. RATE (%)	V.A.T. Net (£)
EMPLOYEE 						
JOB COMPLETED YES ☒ NO ☐		PARTS				
CUSTOMER 		LABOUR				
PRINT NAME LEE A. GAYLE						
ALLOWANCES	AMOUNT	MILEAGE	33			
		TOTAL (£)				

installation in the preceding 24 months.	
--	--

Name* LEE A. GAYLE	
Post SITE SERVICES ENGINEERING SUPERVISOR	
Signature 	
Date 12/07/13	

* authorised to sign on behalf of Vion Food Group (Wales & West of England) Ltd



TOTAL TECHNICAL SERVICES LTD

Refrigeration & Air Conditioning Specialists

Installations, Service and Spares For All Makes of Refrigeration and Air Conditioning Equipment
Industrial, Commercial and Marine

70 Appin Road, Argyle Industrial Estate
Birkenhead, Wirral CH41 9HH
Office: 0151 647 5277
Fax: 0151 210 2641
24hr: 07947634384
Email: enquiries@totaltechnical.co.uk

EMPLOYEE NAME	Kevin P. Smith	CUSTOMER NAME	2 SISTERS
PAYROLL NUMBER		ADDRESS	SPRINGWOOD
JOB NUMBER			
CUSTOMERS O/N/O			
WEEK ENDING (SUN)			

DAY	DATE	STARTED	ENDED	NORM	OVER	PARTS	USED	REQ.	QTY
MON						Refrigerant	✓		1
TUE						Refrigerant	✓		1
WED						Refrigerant	✓		1
THUR									
FRI	5.7.13								
SAT	6.7.13								
SUN									
	TOTALS								


EQUIPMENT	MAKE	MODEL	SERIAL NO.	ASSET NO.	REF	CYLINDER NO.	QTY

WORK REPORT

SISTER 3 UNIT DOWN. CONDENSER LEAKED AND REFRIGERANT
REMOVED. 1 LITRE OF PAID CHECKED AND FOUND OK BY SISTER.
CONDENSER VACUUMED OUT AND RE-CHARGED (FREE) REFRIGERANT.
PACK BACK INTO SYSTEM. PLANT RAN UP AND CHECKED, ALL OK.
MATT CHIEF ENGINEER PUT BACK AND CHECKED PLANT. MONITORED
TO ENSURE NO MIGRATION OF LIQUID FROM MAIN PLANT TOOK
PLACE. ALL LEFT RUNNING SATISFACTORILY.

QUOTE REQUIRED YES ☐ NO ☐ VIA EMAIL ☐ FAX ☐ POST ☐ EMAIL/FAX

AUTHORISING SIGNATURE		DESCRIPTION	QUANTITY	AMOUNT EXC. OF V.A.T. (£)	V.A.T. RATE (%)	V.A.T. AMT (£)
EMPLOYEE		PARTS				
JOB COMPLETED	YES ☒ NO ☐	LABOUR				
CUSTOMER		MILEAGE	33			
PRINT NAME	LEE A. GAYLE	TOTAL (£)				
ALLOWANCES	AMOUNT					



**TOTAL
TECHNICAL
SERVICES Ltd**

Refrigeration & Air Conditioning Specialists

Unit 70 Appin Rd

Argyle Ind Est

Wirral

CH41 9HH

Tel: 0151 647 5277

Fax: 0151 210 2641

Call Out: 0794 763 4384

Email: enquiries@totaltechnical.co.uk

CS Card Registration Numbers

Jon Balkham	Registration No.	4148319
John Hynes	Registration No.	1568873
Kevin Phillips	Registration No.	1670093
Andrew Chalmers	Registration No.	4152165



He awarded to
Kevin Phillips

Information & Technology in the 21st Century

1. The first part of the document is a list of names and addresses, which appears to be a directory or a list of contacts. The names are written in a cursive script, and the addresses are listed below them.

4. 39.2

444

The holder is qualified to undertake lost checking, recovery, installation, service and maintenance of equipment.




Figure 1

1. 2. 3. 4. 5. 6. 7. 8. 9. 10. 11. 12. 13. 14. 15. 16. 17. 18. 19. 20. 21. 22. 23. 24. 25. 26. 27. 28. 29. 30. 31. 32. 33. 34. 35. 36. 37. 38. 39. 40. 41. 42. 43. 44. 45. 46. 47. 48. 49. 50. 51. 52. 53. 54. 55. 56. 57. 58. 59. 60. 61. 62. 63. 64. 65. 66. 67. 68. 69. 70. 71. 72. 73. 74. 75. 76. 77. 78. 79. 80. 81. 82. 83. 84. 85. 86. 87. 88. 89. 90. 91. 92. 93. 94. 95. 96. 97. 98. 99. 100. 101. 102. 103. 104. 105. 106. 107. 108. 109. 110. 111. 112. 113. 114. 115. 116. 117. 118. 119. 120. 121. 122. 123. 124. 125. 126. 127. 128. 129. 130. 131. 132. 133. 134. 135. 136. 137. 138. 139. 140. 141. 142. 143. 144. 145. 146. 147. 148. 149. 150. 151. 152. 153. 154. 155. 156. 157. 158. 159. 160. 161. 162. 163. 164. 165. 166. 167. 168. 169. 170. 171. 172. 173. 174. 175. 176. 177. 178. 179. 180. 181. 182. 183. 184. 185. 186. 187. 188. 189. 190. 191. 192. 193. 194. 195. 196. 197. 198. 199. 200. 201. 202. 203. 204. 205. 206. 207. 208. 209. 210. 211. 212. 213. 214. 215. 216. 217. 218. 219. 220. 221. 222. 223. 224. 225. 226. 227. 228. 229. 230. 231. 232. 233. 234. 235. 236. 237. 238. 239. 240. 241. 242. 243. 244. 245. 246. 247. 248. 249. 250. 251. 252. 253. 254. 255. 256. 257. 258. 259. 260. 261. 262. 263. 264. 265. 266. 267. 268. 269. 270. 271. 272. 273. 274. 275. 276. 277. 278. 279. 280. 281. 282. 283. 284. 285. 286. 287. 288. 289. 290. 291. 292. 293. 294. 295. 296. 297. 298. 299. 300. 301. 302. 303. 304. 305. 306. 307. 308. 309. 310. 311. 312. 313. 314. 315. 316. 317. 318. 319. 320. 321. 322. 323. 324. 325. 326. 327. 328. 329. 330. 331. 332. 333. 334. 335. 336. 337. 338. 339. 340. 341. 342. 343. 344. 345. 346. 347. 348. 349. 350. 351. 352. 353. 354. 355. 356. 357. 358. 359. 360. 361. 362. 363. 364. 365. 366. 367. 368. 369. 370. 371. 372. 373. 374. 375. 376. 377. 378. 379. 380. 381. 382. 383. 384. 385. 386. 387. 388. 389. 390. 391. 392. 393. 394. 395. 396. 397. 398. 399. 400. 401. 402. 403. 404. 405. 406. 407. 408. 409. 410. 411. 412. 413. 414. 415. 416. 417. 418. 419. 420. 421. 422. 423. 424. 425. 426. 427. 428. 429. 430. 431. 432. 433. 434. 435. 436. 437. 438. 439. 440. 441. 442. 443. 444. 445. 446. 447. 448. 449. 450. 451. 452. 453. 454. 455. 456. 457. 458. 459. 460. 461. 462. 463. 464. 465. 466. 467. 468. 469. 470. 471. 472. 473. 474. 475. 476. 477. 478. 479. 480. 481. 482. 483. 484. 485. 486. 487. 488. 489. 490. 491. 492. 493. 494. 495. 496. 497. 498. 499. 500. 501. 502. 503. 504. 505. 506. 507. 508. 509. 510. 511. 512. 513. 514. 515. 516. 517. 518. 519. 520. 521. 522. 523. 524. 525. 526. 527. 528. 529. 530. 531. 532. 533. 534. 535. 536. 537. 538. 539. 540. 541. 542. 543. 544. 545. 546. 547. 548. 549. 550. 551. 552. 553. 554. 555. 556. 557. 558. 559. 560. 561. 562. 563. 564. 565. 566. 567. 568. 569. 570. 571. 572. 573. 574. 575. 576. 577. 578. 579. 580. 581. 582. 583. 584. 585. 586. 587. 588. 589. 590. 591. 592. 593. 594. 595. 596. 597. 598. 599. 600. 601. 602. 603. 604. 605. 606. 607. 608. 609. 610. 611. 612. 613. 614. 615. 616. 617. 618. 619. 620. 621. 622. 623. 624. 625. 626. 627. 628. 629. 630. 631. 632. 633. 634. 635. 636. 637. 638. 639. 640. 641. 642. 643. 644. 645. 646. 647. 648. 649. 650. 651. 652. 653. 654. 655. 656. 657. 658. 659. 660. 661. 662. 663. 664. 665. 666. 667. 668. 669. 670. 671. 672. 673. 674. 675. 676. 677. 678. 679. 680. 681. 682. 683. 684. 685. 686. 687. 688. 689. 690. 691. 692. 693. 694. 695. 696. 697. 698. 699. 700. 701. 702. 703. 704. 705. 706. 707. 708. 709. 710. 711. 712. 713. 714. 715. 716. 717. 718. 719. 720. 721. 722. 723. 724. 725. 726. 727. 728. 729. 730. 731. 732. 733. 734. 735. 736. 737. 738. 739. 740. 741. 742. 743. 744. 745. 746. 747. 748. 749. 750. 751. 752. 753. 754. 755. 756. 757. 758. 759. 760. 761. 762. 763. 764. 765. 766. 767. 768. 769. 770. 771. 772. 773. 774. 775. 776. 777. 778. 779. 780. 781. 782. 783. 784. 785. 786. 787. 788. 789. 790. 791. 792. 793. 794. 795. 796. 797. 798. 799. 800. 801. 802. 803. 804. 805. 806. 807. 808. 809. 810. 811. 812. 813. 814. 815. 816. 817. 818. 819. 820. 821. 822. 823. 824. 825. 826. 827. 828. 829. 830. 831. 832. 833. 834. 835. 836. 837. 838. 839. 840. 84

[illegible][illegible]

Medal Book

Chis Jones



4. Personal
 (Signature)
 The City and County of London officials

City Trust
Director General
 The City and County of London Institute





060



CERTIFICATE OF REGISTRATION

Certificate Number

7356

This Certificate has been awarded to:

Total Technical Services Ltd.

**70 Appin Road
Argyle Industrial Estate
Wirral
CH41 9HH**

Date First Registered

14/12/2011

*In Recognition of the Organisation's Management
System which complies with:*

ISO 9001:2008

Date Certificate Expires

08/11/2014

For the Scope of Activities described below:

Refrigeration & Air Conditioning Service & Repair

*World Certification Services Ltd.
1st Floor, 52A Mersey View
Merseyside, L22 6QB
United Kingdom*

This Certificate has been awarded by

WORLD CERTIFICATION SERVICES LTD.

Issued By:

Issue Date:

14/12/2011

*The use of the accreditation mark indicates accreditation in respect
of those activities covered by accreditation certificate number 60*

