

Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provision of the EP Regulations.

Part A

Permit number	EPR/CB3091HY
Name of operator	Cambrian Pet Foods Ltd
Location of Facility	Tywi Valley Food Park Station Road Llangadog Carmarthenshire SA19 9LN
Time and date of the detection	June 2022

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified within 24 hours	
Date and time of the event	
Reference or description of the location or the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of the quantity of rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

(b) Notification requirements for the breach of a permit condition	
To be notified within 24 hours	
Emission point reference/source	Point S1 on site plan in Schedule 7 emission to Afon Tywi
Parameter(s)	Maximum daily discharge volume
Limit	1000m ³
Measured value and uncertainty	Measured value as per recorded data from the MCERTS calibrated Outflow Meter. Uncertainty value +/- 3.9%. The measured value also includes any surface water from rainfall that enters the ETP via site drainage.

Date and time of monitoring	20.06.22 at 23.59 auto flow meter reading 1018.68m ³ 22.06.22 at 23.57 auto flow meter reading 1024.66m ³ 28.06.22 at 23.57 auto flow meter reading 1147.72m ³
Measures taken, or intended to be taken, to stop the emission	All required water tests were carried out on each breach date, were within permit specifications. The engineering Management are looking into solutions to reduce water usage and reuse water where possible. Weather station is monitored for heavy rainfall. Rain water is discharged via the ETP due to site land drainage design.

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses and immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment: To be notified within 24 hours	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	Outflow breach 20.06.22 – this was due to high amount of rainfall that occurred on the weekend previously (see attached evidence with weather station rainfall graphs). ETP not in operation during the weekend so accumulation of water is sent out on the Monday. Outflow breach 22.06.22 – Investigation for the excess of 24m³ is still ongoing. Outflow breach 28.06.22 – This was due to heavy rainfall at the site location. (see attached evidence with weather station rainfall graphs). All 3 dates corresponded to Chunk Production days where the site uses and therefore expels more water, compared to producing Loaf Product.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	All discharge water was within permit limits during daily testing, so no threat to environment.

Measures taken, or intended to be taken, to rectify limit or prevent any pollution of the environment which has been or may be caused by the emission	The Engineering department have a project looking into site drainage as currently the 17acre site land surface drainage all exits via the ETP and also reducing water usage where possible on site. Daily testing of the outflow water to ensure all water is within permit limits. Any breach of outflow limit is investigated fully. A weather station is in place to monitor rainfall. Outflow meter is MCERTS calibrated.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	N/A

Name*	Chris Moore
Post	Head of Technical
Signature	
Date	08.07.22

*authorised to sign on behalf of the operator

