RECEIVED
21 JAN 2014

Permit Reference Number: VP3030BX

Operator: Befesa Salt Slags Ltd

Installation: Whitchurch Salt Slags

Form Number: A1

Reporting of Emissions to Air for the period……Q4……2013……..

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date and Times [3]	Accreditation/ Certification [4]	Uncertainty [5]
A1	Particulate (mg/m^3)	12	*9.4 mg/m3*	*BS EN 13284*	*12/12/13 09:35 – 10:36*	*MCERTS UKAS*	*+/- 0.36*
A2	Ammonia (mg/m^3)	15	*1.4 mg/m3*	*SRM-BS EN 14791*	*12/12/13 10:50-11:50*	*MCERTS UKAS*	*+/- 0.17*
A5	Ammonia (mg/m^3)	15	*0.29 mg/m3*	*SRM-BS EN 14791*	*12/12/13 09:25 – 10:25*	*MCERTS UKAS*	*+/- 0.04*

Operator's comments :
Plant operating under normal conditions at the time of sampling

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period.
[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed ……

(authorised to sign as representative of the Operator)

Date 21/1/2014

MONITORING RETURNS N. WALES
INITIALS DATE
CHECKED Vs AUTHORISATION AS 21-1-14
TRACKING JB 21-1-14
OK FOR PUBLIC REGISTER AS 21-1-14
JB EDRM

Permit Reference Number: VP3030BX

Operator: Befesa Salt Slags Ltd

Installation: Whitchurch Salt Slags

Form Number: A1

Reporting of Emissions to Air for the period. Q4 2013

Emission Point	Substance / Parameter	Emission Limit Value	Result [1]	Test Method [2]	Sample Date and Times [3]	Accreditation/ Certification [4]	Uncertainty [5]
A6	Ammonia (mg/m^3)	15	*0.59 mg/m3*	*SRM-BS EN 14791*	*12/12/13 12:15 – 13:15*	*MCERTS UKAS*	*+/- 0.07*

Operator's comments :
Normal operating conditions at the time of monitoring

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period.
[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. gas chromatography.
[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.
[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed .....

(authorised to sign as representative of the Operator)

Date 20/1/2014