

Permit Reference Number: BV8024IW

Operator: Glanbia Cheese Limited

Installation: Llangefni Dairy

Form Number: W1

Reporting of Emissions to Surface Water for the period from 1-7-15 to 30-9-15

Emission Point	Substance / Parameter	Discharge Limits	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Accreditation/ Certification ^[4]	Uncertainty ^[5]
W2	BOD	6 mg/l	3.7	Q1 251/17	2.9.15 10.00	UKAS	+ - 0.2078 mg/L
W2	Suspended Solids	30 mg/l	<6	Q1 250/12	" "	"	+ - 0.138 mg/L
W2	Oil and Grease	10 mg/l	<8	Q1 251/10	" "	"	+ - 1.7 mg/L
W2	pH	>6 - <9	7.34	Q1 251/46	" "	"	+ - 0.2 units
W2	Biocide and Slimicide	Not detectable	-	-	-	-	-

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum - maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(authorised to sign as representative of the Operator)

Date: 9-10-15