



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

Glanbia Cheese Limited
Glan Hwfa Road
Llangefni
Isle of Anglesey
Wales
LL77 7TT

15th August 2014

Dear Mr Walkden

EPR/BV8024IW: Review of Flow Meter Requirements at S1

Permit Section 2.10.2 requires that total flow is measured for S1 using a continuous flow meter.

An MCERTS flume meter is used at present to measure flow for the above permit requirement. The site also has a trade effluent consent with Welsh Water and use a magnetic flow meter which is more accurate than the flume meter, although it is not MCERTS accredited. The operator has requested that this meter be used for permit reporting in place of the flume meter.

Natural Resources Wales agrees that as there is no emission limit value set for flow, and the discharge is to sewer for which limits are set with Welsh Water, the site can use the magnetic flow meter readings in future for permit reporting.

Yours sincerely

Elizabeth Voice
Regulatory Officer
PPC/RSR

Ffôn/Tel 01244 894602

Ffacs/Fax 01244 550144

Ebost/Email elizabeth.voice@naturalresourceswales.gov.uk

www.cyfoethnaturiolcymru.gov.uk www.naturalresourceswales.gov.uk

Chester Road, Buckley, Flintshire, CH7 3AJ.

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg
Correspondence welcomed in Welsh and English

ON FOR PUBLIC REGISTER	DATE	20.8.14
COPIED TO PUBLIC REGISTER	JB	EDRM